



e-beam 
engineered LVL beams

Wesbeam e-beam Span Tables

Roof Members

Rafters	4
Roof Beams	6
Strutting Beams	8
Strutting-Counter Beams	10
Strutting-Hanging Beams	11
Counter Beams	12
Verandah Beams	13

Wall Members

Lintels	
Lintels - In Single or Upper Storey Load Bearing External Walls	17
Lintels - In Lower Storey Load Bearing External Walls	18
Lintels - Supporting Truncated Girder Truss	20
Lintels - Supporting Strutting Beams	21

Floor Members

Floor Joists	
Floor Joists - Supporting Floor Loads Only	22
Floor Joists - For Tiled Floors or Floors Supporting Heavy Furniture	23
Floor Joists - Supporting Parallel Load Bearing Walls Over Openings	24

Bearers

Bearers - Supporting Floor Loads Only	25
Bearers - Supporting Single or Upper Storey Load Bearing Walls	26
Bearers - Supporting Two Storey Load Bearing Walls	28

e-beam is the premier laminated veneer lumber (LVL) product available in Australia. LVL has many advantages over traditional building products, including its uniformity of engineering properties, its high strength to weight ratio and its availability in longer lengths.

Available in a range of thicknesses including 35mm, 42mm, 57mm and 75mm with depths from 95mm to 450mm, e-beam is manufactured from plantation timbers, making it an environmentally sustainable resource.

About e-beam	e-beam conforms with the requirements of AS/NZS 4357 Structural Laminated Veneer Lumber. It is manufactured by laminating Maritime Pine and/or Radiata Pine veneer, using phenolic adhesive, in a continuous assembly in which the grain direction of all veneers runs longitudinally. It is pressed as a 1.2 m nominal width continuous billet in various standard thicknesses, cut to standard widths and any specified length for use as structural beams and other framing components.
Use of e-beam Data	The Tables and other technical data provided in this publication are only applicable to e-beam LVL manufactured by Wesbeam. This data should not be used for look-alike or substitute products. Use of the e-beam data for look-alike or substitute products can result in unsafe or unsatisfactory performance.
Basis for Design	The design criteria used to develop the Span Tables contained in this brochure are based on the assumptions listed in AS1684.1 – 1999 Residential timber framed construction design criteria.
Design Loads	<p>The design loads used to determine member sizes listed in the Span Tables are as per AS1684.1 – 1999 Residential timber framed construction design criteria. The design loads include:-</p> <ul style="list-style-type: none">• Dead loads• Live loads• Wind loads• Snow loads• Earthquake loads, and• Load Combinations of the above loads <p>Design load limitations for each of the above load or load combination cases are also as per AS1684.1 – 1999 Residential timber framed construction.</p>
Design Capacity Factor (ϕ)	The capacity factor (ϕ) used to calculate the design capacity of a structural framing member listed in the Span Tables is taken from AS1720.1 – 2010 where for all LVL structural elements used in residential houses $\phi = 0.9$.
Terminology, Definitions & Notations Used in these Tables	The terminology, definitions and notations used in this brochure are similar to and consistent with those used and listed in AS1684.2 – 2010 Residential timber framed construction.

Using Multiple Sections

The use of multiple sections where called for in the Span Tables is permitted using vertically nail laminated LVL. Multiple LVL members are to be fixed in accordance with Cl 2.3 of AS1684.2 – 2010.

Characteristic Design Values

The characteristic Design Values for Wesbeam e-beam LVL are available on request from Wesbeam's Technical Department. This service is available for professional design practitioners.

The spans listed in this brochure for e-beam LVL manufactured by Wesbeam apply only when the moisture content of the LVL is below 15% in service and are for "on edge" orientation of the LVL section.

Rafters

For N3 wind classification

e-beam Section D X B (mm)	Roof Mass kg/ m ²	Single Span								Continuous Span							
		Maximum Rafter Spacing (mm)															
		450		600		900		1200		450		600		900		1200	
		Maximum Rafter Span and Overhang 'O/H' (m)															
		SPAN	O/H	SPAN	O/H	SPAN	O/H	SPAN	O/H	SPAN	O/H	SPAN	O/H	SPAN	O/H	SPAN	O/H
95 x 35	10	3.3	0.7	3.2	0.5	2.9	0.6	2.7	0.4	4.3	0.6	3.9	0.5	3.5	0.6	3.2	0.4
	20	3.2	0.7	3.0	0.6	2.8	0.5	2.5	0.6	4.3	0.6	3.9	0.5	3.5	0.6	3.2	0.5
	30	3.0	0.7	2.8	0.6	2.5	0.7	2.2	0.5	4.1	0.6	3.7	0.5	3.3	0.6	3.0	0.5
	40	2.8	0.8	2.5	0.6	2.2	0.7	2.1	0.5	3.7	0.7	3.4	0.5	3.0	0.6	2.8	0.5
	60	2.5	0.8	2.2	0.7	2.0	0.6	1.8	0.5	3.3	0.7	3.0	0.6	2.6	0.7	2.4	0.5
	75	2.3	0.8	2.1	0.7	1.8	0.6	1.7	0.5	3.1	0.7	2.8	0.6	2.5	0.7	2.2	0.5
	90	2.2	0.8	2.0	0.7	1.7	0.8	1.6	0.6	2.9	0.7	2.6	0.6	2.3	0.7	2.1	0.6
95 x42	10	3.7	0.7	3.5	0.6	3.2	0.7	3.0	0.5	4.8	0.6	4.4	0.5	3.9	0.6	3.6	0.5
	20	3.5	0.8	3.3	0.6	3.0	0.7	2.7	0.5	4.8	0.6	4.4	0.5	3.9	0.6	3.6	0.5
	30	3.2	0.8	3.0	0.6	2.6	0.7	2.4	0.5	4.3	0.7	4.0	0.5	3.5	0.6	3.2	0.5
	40	3.0	0.8	2.7	0.7	2.4	0.7	2.2	0.6	4.0	0.7	3.7	0.6	3.2	0.7	3.0	0.5
	60	2.6	0.9	2.4	0.7	2.1	0.8	1.9	0.6	3.5	0.8	3.2	0.6	2.8	0.7	2.6	0.6
	75	2.5	0.9	2.2	0.8	2.0	0.7	1.8	0.6	3.3	0.8	3.0	0.6	2.6	0.7	2.4	0.6
	90	2.3	0.9	2.1	0.8	1.9	0.7	1.7	0.6	3.1	0.8	2.8	0.7	2.5	0.6	2.3	0.7
130 x 35	10	5.3	0.9	4.8	0.7	4.2	0.8	3.8	0.6	6.7	0.8	5.9	0.6	4.9	0.8	4.3	0.6
	20	4.5	1.0	4.2	0.8	3.8	0.7	3.5	0.6	6.1	0.8	5.6	0.6	5.0	0.8	4.4	0.6
	30	4.1	1.0	3.8	0.8	3.3	0.7	3.1	0.6	5.4	0.9	5.0	0.7	4.5	0.6	4.1	0.8
	40	3.8	1.0	3.5	0.8	3.1	0.9	2.8	0.6	5.0	0.9	4.6	0.7	4.1	0.8	3.7	0.6
	60	3.3	1.1	3.1	0.9	2.7	0.8	2.5	0.7	4.5	1.0	4.1	0.8	3.6	0.7	3.3	0.9
	75	3.1	1.1	2.9	0.9	2.5	0.8	2.3	0.7	4.2	1.0	3.8	0.8	3.4	0.9	3.1	0.7
	90	2.9	1.2	2.7	1.0	2.4	0.9	2.2	0.7	3.9	1.0	3.6	0.8	3.2	0.9	2.9	0.7
130 x 42	10	5.5	1.0	5.2	0.8	4.5	0.7	4.1	0.9	7.4	0.8	6.9	0.6	5.7	0.8	4.9	0.7
	20	4.8	1.0	4.4	0.8	4.0	0.9	3.7	0.7	6.4	0.9	6.0	0.7	5.4	0.8	4.9	0.7
	30	4.3	1.1	4.0	0.9	3.6	0.8	3.3	0.7	5.8	0.9	5.4	0.7	4.8	0.9	4.4	0.7
	40	4.0	1.1	3.7	0.9	3.3	1.0	3.0	0.7	5.4	1.0	4.9	0.8	4.4	0.9	4.0	0.7
	60	3.6	1.2	3.3	1.0	2.9	0.9	2.6	0.8	4.8	1.0	4.4	0.8	3.9	0.9	3.5	0.8
	75	3.3	1.2	3.1	1.0	2.7	1.1	2.5	0.8	4.5	1.1	4.1	0.9	3.6	0.8	3.3	1.0
	90	3.2	1.2	2.9	1.0	2.5	1.1	2.3	0.8	4.2	1.1	3.9	0.9	3.4	1.0	3.1	0.8
150 x 35	10	6.0	0.8	5.5	1.0	4.8	0.8	4.4	0.7	7.4	0.9	6.5	0.7	5.5	0.9	4.9	0.7
	20	5.1	1.1	4.8	0.9	4.3	0.8	4.0	0.7	6.9	0.9	6.4	0.7	5.7	0.9	5.0	0.7
	30	4.6	1.2	4.3	0.9	3.8	0.8	3.5	0.7	6.2	1.0	5.8	0.8	5.1	0.7	4.7	0.9
	40	4.3	1.2	4.0	1.0	3.5	0.9	3.2	0.7	5.8	1.0	5.3	0.8	4.7	1.0	4.3	0.7
	60	3.8	1.3	3.5	1.0	3.1	0.9	2.8	0.8	5.1	1.1	4.7	0.9	4.2	0.8	3.8	1.0
	75	3.6	1.3	3.3	1.1	2.9	1.0	2.6	0.8	4.8	1.1	4.4	0.9	3.9	1.0	3.5	0.8
	90	3.4	1.3	3.1	1.1	2.7	1.0	2.5	0.8	4.5	1.2	4.2	0.9	3.7	1.1	3.3	0.8
150 x 42	10	6.2	1.1	5.9	0.9	5.2	1.0	4.7	0.8	8.3	1.0	7.8	0.7	6.5	0.9	5.6	0.8
	20	5.4	1.2	5.1	1.0	4.6	0.9	4.2	0.8	7.3	1.0	6.8	0.8	6.1	0.9	5.7	0.7
	30	4.9	1.3	4.6	1.0	4.1	1.1	3.8	0.8	6.6	1.1	6.1	0.9	5.5	0.8	5.0	1.0
	40	4.6	1.3	4.2	1.1	3.8	1.0	3.4	0.8	6.1	1.1	5.7	0.9	5.0	1.0	4.6	0.8
	60	4.1	1.4	3.8	1.1	3.3	1.0	3.0	0.9	5.5	1.2	5.0	1.0	4.4	0.9	4.1	1.1
	75	3.8	1.4	3.5	1.2	3.1	1.1	2.8	0.9	5.1	1.2	4.7	1.0	4.2	1.1	3.8	0.9
	90	3.6	1.4	3.3	1.2	2.9	1.1	2.7	1.0	4.9	1.3	4.4	1.0	3.9	1.2	3.6	1.0
170 x 35	10	6.6	1.2	6.3	0.9	5.5	1.1	5.0	0.8	8.1	1.0	7.2	0.8	6.0	1.0	5.3	0.8
	20	5.8	1.2	5.4	1.0	4.8	0.9	4.5	0.8	7.7	1.1	7.2	0.8	6.2	1.0	5.5	0.8
	30	5.2	1.3	4.8	1.1	4.3	0.9	4.0	0.8	7.0	0.9	6.5	1.1	5.8	0.8	5.3	1.0
	40	4.8	1.4	4.5	1.1	4.0	1.0	3.6	0.8	6.5	1.2	6.0	0.9	5.3	1.1	4.9	0.8
	60	4.3	1.4	4.0	1.2	3.5	1.0	3.2	0.9	5.8	1.0	5.3	1.2	4.7	1.0	4.3	0.9
	75	4.0	1.5	3.7	1.2	3.3	1.1	3.0	0.9	5.4	1.3	5.0	1.0	4.4	1.2	4.0	0.9
	90	3.8	1.5	3.5	1.3	3.1	1.1	2.8	0.9	5.1	1.3	4.7	1.1	4.1	1.0	3.8	0.9
170 x 42	10	6.9	1.3	6.6	1.0	5.9	1.2	5.4	0.9	9.2	1.1	8.6	0.8	7.1	1.1	6.3	0.9
	20	6.1	1.4	5.7	1.1	5.1	1.0	4.7	0.9	8.1	1.2	7.6	0.9	6.9	1.1	6.4	0.8
	30	5.5	1.4	5.1	1.2	4.6	1.1	4.2	0.9	7.4	1.2	6.9	1.0	6.2	0.9	5.7	1.1
	40	5.1	1.5	4.7	1.2	4.2	1.1	3.9	0.9	6.9	1.3	6.4	1.0	5.7	1.2	5.2	0.9
	60	4.6	1.5	4.2	1.3	3.7	1.2	3.4	1.0	6.2	1.3	5.7	1.1	5.0	1.2	4.6	1.0
	75	4.3	1.6	4.0	1.3	3.5	1.2	3.2	1.0	5.8	1.4	5.3	1.1	4.7	1.3	4.3	1.0
	90	4.1	1.6	3.7	1.4	3.3	1.3	3.0	1.1	5.5	1.4	5.0	1.2	4.4	1.1	4.0	1.3

Rafters continued

For N3 wind classification

e-beam Section D X B (mm)	Roof Mass kg/ m ²	Single Span								Continuous Span									
		Maximum Rafter Spacing (mm)																	
		450		600		900		1200		450		600		900		1200			
		Maximum Rafter Span and Overhang 'O/H' (m)																	
SPAN		O/H		SPAN		O/H		SPAN		O/H		SPAN		O/H		SPAN		O/H	
200 x 35	10	7.6	1.4	7.2	1.1	6.4	1.0	5.7	0.9	9.1	1.3	7.8	1.0	6.6	1.2	6.0	0.9		
	20	6.7	1.5	6.2	1.2	5.6	1.1	5.2	0.9	8.9	1.3	8.1	1.0	6.8	1.2	6.1	0.9		
	30	6.1	1.5	5.6	1.3	5.0	1.1	4.6	0.9	8.1	1.3	7.5	1.0	6.8	1.2	6.2	0.9		
	40	5.6	1.6	5.2	1.3	4.6	1.1	4.3	0.9	7.5	1.4	7.0	1.1	6.2	1.0	5.7	0.9		
	60	5.0	1.7	4.6	1.4	4.1	1.2	3.8	1.0	6.8	1.5	6.2	1.2	5.5	1.1	5.0	1.0		
	75	4.7	1.7	4.3	1.4	3.8	1.2	3.5	1.0	6.3	1.5	5.8	1.2	5.1	1.4	4.7	1.0		
	90	4.5	1.8	4.1	1.5	3.6	1.3	3.3	1.1	6.0	1.6	5.5	1.3	4.8	1.2	4.4	1.1		
200 x 42	10	7.9	1.5	7.5	1.2	6.9	1.1	6.3	1.0	NS	NS	NS	NS	8.0	1.3	7.0	1.0		
	20	7.0	1.6	6.6	1.3	6.0	1.2	5.5	1.0	9.3	1.4	8.8	1.1	8.0	1.0	7.2	1.3		
	30	6.4	1.7	6.0	1.4	5.4	1.2	4.9	1.0	8.6	1.5	8.0	1.2	7.2	1.1	6.6	1.0		
	40	6.0	1.7	5.5	1.4	4.9	1.3	4.5	1.1	8.0	1.5	7.4	1.2	6.6	1.4	6.1	1.1		
	60	5.4	1.8	4.9	1.5	4.4	1.3	4.0	1.1	7.2	1.6	6.6	1.3	5.9	1.2	5.4	1.1		
	75	5.0	1.9	4.6	1.6	4.1	1.4	3.8	1.2	6.8	1.6	6.2	1.3	5.5	1.5	5.0	1.2		
	90	4.8	1.9	4.4	1.6	3.9	1.5	3.5	1.2	6.4	1.7	5.9	1.4	5.2	1.3	4.7	1.2		
240 x 42	10	9.1	1.9	8.7	1.5	8.1	1.4	7.5	1.2	NS	NS	NS	NS	9.3	1.5	8.0	1.2		
	20	8.2	2.0	7.7	1.6	7.0	1.4	6.6	1.2	NS	NS	NS	NS	9.4	1.2	8.2	1.6		
	30	7.5	2.0	7.0	1.7	6.4	1.4	5.9	1.2	NS	NS	9.4	1.4	8.5	1.3	7.9	1.2		
	40	7.0	2.1	6.6	1.7	5.9	1.5	5.4	1.2	9.4	1.8	8.8	1.5	7.9	1.4	7.3	1.2		
	60	6.4	2.2	5.9	1.8	5.2	1.6	4.8	1.3	8.5	1.9	7.9	1.6	7.0	1.5	6.4	1.3		
	75	6.0	2.3	5.5	1.9	4.9	1.6	4.5	1.4	8.0	2.0	7.4	1.6	6.6	1.5	6.0	1.4		
	90	5.7	2.3	5.2	1.9	4.6	1.7	4.2	1.4	7.6	2.0	7.0	1.7	6.2	1.6	5.7	1.4		
240 x 57	10	9.5	2.1	9.2	1.7	8.6	1.6	8.2	1.4	NS	NS	NS	NS	NS	NS	NS	NS		
	20	8.6	2.3	8.2	1.9	7.6	1.7	7.1	1.4	NS	NS	NS	NS	NS	NS	9.5	1.4		
	30	8.1	2.3	7.6	1.9	6.9	1.8	6.4	1.5	NS	NS	NS	NS	9.3	1.5	8.6	1.8		
	40	7.6	2.4	7.1	2.0	6.4	1.8	6.0	1.5	NS	NS	9.5	1.7	8.6	1.6	8.0	1.5		
	60	6.9	2.5	6.4	2.1	5.8	1.9	5.3	1.6	9.3	2.2	8.6	1.8	7.7	1.7	7.1	1.6		
	75	6.5	2.6	6.1	2.2	5.4	2.0	5.0	1.7	8.8	2.2	8.1	1.9	7.3	1.8	6.7	1.7		
	90	6.2	2.6	5.8	2.2	5.1	2.1	4.7	1.8	8.4	2.3	7.7	1.9	6.9	1.8	6.3	2.0		
300 x 42	10	10.8	2.4	10.5	1.9	9.6	1.7	8.8	1.4	NS	NS	NS	NS	NS	NS	NS	NS		
	20	9.8	2.5	9.4	2.0	8.6	1.7	8.0	1.4	NS	NS	NS	NS	NS	NS	NS	NS		
	30	9.1	2.6	8.6	2.1	7.8	1.7	7.2	1.5	NS	NS	NS	NS	NS	NS	NS	NS		
	40	8.6	2.7	8.0	2.2	7.2	1.8	6.7	1.5	NS	NS	NS	NS	NS	NS	9.0	1.5		
	60	7.8	2.8	7.2	2.3	6.5	1.9	6.0	1.6	NS	NS	NS	NS	8.7	1.9	8.0	1.6		
	75	7.4	2.8	6.8	2.4	6.1	2.0	5.6	1.7	NS	NS	9.1	2.0	8.1	1.9	7.5	1.7		
	90	7.0	2.9	6.5	2.4	5.8	2.1	5.3	1.8	9.4	2.5	8.7	2.1	7.7	2.0	7.1	1.8		
300 x 57	10	11.2	2.8	10.9	2.2	10.4	2.0	9.7	1.7	NS	NS	NS	NS	NS	NS	NS	NS		
	20	10.4	2.9	9.9	2.4	9.2	2.1	8.7	1.8	NS	NS	NS	NS	NS	NS	NS	NS		
	30	9.7	3.0	9.2	2.5	8.5	2.1	7.9	1.8	NS	NS	NS	NS	NS	NS	NS	NS		
	40	9.2	3.0	8.7	2.5	7.9	2.2	7.3	1.8	NS	NS	NS	NS	NS	NS	NS	NS		
	60	8.5	3.1	7.9	2.6	7.1	2.3	6.6	2.0	NS	NS	NS	NS	9.5	2.2	8.8	2.0		
	75	8.0	3.2	7.5	2.7	6.7	2.4	6.2	2.0	NS	NS	NS	NS	9.0	2.2	8.3	2.0		
	90	7.7	3.3	7.1	2.8	6.4	2.5	5.8	2.1	NS	NS	9.5	2.4	8.5	2.3	7.8	2.1		
350 x 42	10	12.5	2.9	12.1	2.3	10.1	2.0	8.6	1.6	NS	NS	NS	NS	NS	NS	NS	NS		
	20	11.5	3.0	10.9	2.4	10.1	2.0	8.9	1.7	NS	NS	NS	NS	NS	NS	NS	NS		
	30	10.7	3.1	10.1	2.5	9.2	2.0	8.6	1.7	NS	NS	NS	NS	NS	NS	NS	NS		
	40	10.1	3.2	9.5	2.6	8.6	2.1	8.0	1.8	NS	NS	NS	NS	NS	NS	NS	NS		
	60	9.2	3.3	8.6	2.8	7.7	2.2	7.1	1.9	NS	NS	NS	NS	9.5	2.2	8.8	1.9		
	75	8.7	3.4	8.1	2.8	7.2	2.3	6.6	2.0	NS	NS	NS	NS	9.0	2.3	8.2	2.0		
	90	8.3	3.5	7.7	2.9	6.9	2.4	6.3	2.1	NS	NS	9.5	2.6	8.5	2.4	7.7	2.1		
400 x 57	10	13.9	3.8	13.6	3.1	12.9	2.6	12.0	2.2	NS	NS	NS	NS	NS	NS	NS	NS		
	20	13.0	3.9	12.6	3.2	11.8	2.7	11.2	2.3	NS	NS	NS	NS	NS	NS	NS	NS		
	30	12.4	4.0	11.8	3.3	10.9	2.7	10.3	2.3	NS	NS	NS	NS	NS	NS	NS	NS		
	40	11.8	4.1	11.2	3.4	10.3	2.8	9.6	2.4	NS	NS	NS	NS	NS	NS	NS	NS		
	60	10.9	4.2	10.3	3.6	9.3	3.0	8.6	2.5	NS	NS	NS	NS	NS	NS	NS	NS		
	75	10.4	4.3	9.7	3.7	8.8	3.1	8.1	2.6	NS	NS	NS	NS	NS	NS	NS	NS		
	90	10.0	4.4	9.3	3.7	8.3	3.3	7.7	2.8	13.4	3.9	12.5	3.2	11.2	3.1	10.3	2.8		

NS indicates that this span is not available due to manufacturing and transport length limitations

Roof Beams

Ridge, Intermediate, Eave and Bressummer Beams
For N3 wind classification

e-beam Section D X B (mm)	Sheet Roof and Ceiling											
	Roof Load Width 'RLW' (m)											
	1.8	2.1	2.4	2.7	3.0	3.3	3.6	3.9	4.2	4.8	5.4	6.0
Maximum Single Span (m)												
150 x 35	2.8	2.6	2.5	2.4	2.3	2.2	2.1	2.1	2.0	1.9	1.8	1.8
150 x 42	3.0	2.8	2.7	2.6	2.5	2.4	2.3	2.2	2.2	2.1	2.0	1.9
170 x 35	3.1	3.0	2.8	2.7	2.6	2.5	2.4	2.4	2.3	2.2	2.1	2.0
170 x 42	3.3	3.2	3.0	2.9	2.8	2.7	2.6	2.5	2.5	2.3	2.2	2.1
200 x 35	3.7	3.5	3.3	3.2	3.1	2.9	2.9	2.8	2.7	2.6	2.4	2.3
200 x 42	3.9	3.7	3.5	3.4	3.3	3.2	3.1	3.0	2.9	2.7	2.6	2.5
200 x 57	4.3	4.1	3.9	3.8	3.6	3.5	3.4	3.3	3.2	3.1	2.9	2.8
240 x 35	4.4	4.1	4.0	3.8	3.7	3.5	3.4	3.3	3.2	3.1	2.8	2.7
240 x 42	4.7	4.4	4.2	4.1	3.9	3.8	3.7	3.6	3.5	3.3	3.1	3.0
240 x 57	5.2	4.9	4.7	4.5	4.4	4.2	4.1	4.0	3.9	3.7	3.5	3.4
300 x 42	5.8	5.5	5.3	5.1	4.9	4.7	4.6	4.4	4.3	4.1	3.9	3.8
300 x 57	6.4	6.1	5.8	5.6	5.4	5.2	5.1	4.9	4.8	4.6	4.4	4.2
300 x 75	6.7	6.4	6.2	5.9	5.7	5.5	5.4	5.2	5.1	4.8	4.6	4.4
350 x 57	7.6	7.3	7.0	6.7	6.5	6.3	6.1	5.9	5.7	5.5	5.2	5.0
400 x 42	7.7	7.3	7.0	6.7	6.4	6.1	5.9	5.7	5.5	5.1	4.8	4.6
400 x 57	8.4	8.0	7.7	7.4	7.2	6.9	6.7	6.5	6.4	6.1	5.8	5.6
400 x 75	8.8	8.4	8.1	7.8	7.5	7.3	7.1	6.9	6.7	6.4	6.1	5.9
450 x 57	9.4	9.0	8.6	8.3	8.0	7.8	7.5	7.3	7.1	6.8	6.5	6.3
Maximum Continuous Span (m)												
150 x 35	3.7	3.5	3.3	3.2	3.1	3.0	2.9	2.8	2.7	2.6	2.5	2.3
150 x 42	4.0	3.8	3.6	3.4	3.3	3.2	3.1	3.0	2.9	2.8	2.6	2.5
170 x 35	4.2	4.0	3.8	3.6	3.5	3.4	3.3	3.2	3.1	2.9	2.8	2.6
170 x 42	4.5	4.2	4.1	3.9	3.7	3.6	3.5	3.4	3.3	3.1	3.0	2.9
200 x 35	4.9	4.6	4.4	4.2	4.1	3.9	3.8	3.7	3.5	3.3	3.2	3.0
200 x 42	5.2	5.0	4.8	4.6	4.4	4.2	4.1	4.0	3.9	3.7	3.5	3.4
200 x 57	5.8	5.5	5.3	5.1	4.9	4.7	4.6	4.4	4.3	4.1	3.9	3.8
240 x 35	5.8	5.4	5.1	4.9	4.7	4.4	4.3	4.1	4.0	3.8	3.6	3.5
240 x 42	6.3	6.0	5.7	5.5	5.3	5.1	4.9	4.8	4.6	4.4	4.2	4.0
240 x 57	6.9	6.6	6.3	6.1	5.8	5.7	5.5	5.3	5.2	4.9	4.7	4.5
300 x 42	7.8	7.3	7.0	6.6	6.3	6.1	5.9	5.7	5.5	5.2	5.0	4.7
300 x 57	8.6	8.2	7.8	7.5	7.3	7.0	6.8	6.6	6.4	6.1	5.9	5.6
300 x 75	9.0	8.6	8.2	7.9	7.7	7.4	7.2	7.0	6.8	6.5	6.2	5.9
350 x 57	10.2	9.7	9.3	9.0	8.7	8.4	8.1	7.9	7.7	7.3	7.0	6.7
400 x 42	8.6	8.1	7.8	7.5	7.2	7.0	6.7	6.5	6.3	6.0	5.7	5.5
400 x 57	11.3	10.8	10.3	9.9	9.6	9.3	8.9	8.7	8.3	7.9	7.5	7.2
400 x 75	11.8	11.3	10.9	10.5	10.1	9.8	9.5	9.2	9.0	8.6	8.2	7.9

Roof Beams

Ridge, Intermediate, Eave and Bressummer Beams
For N3 wind classification

e-beam Section D X B (mm)	Tile Roof and Ceiling											
	Roof Load Width 'RLW' (m)											
	1.8	2.1	2.4	2.7	3.0	3.3	3.6	3.9	4.2	4.8	5.4	6.0
Maximum Single Span (m)												
150 x 35	2.2	2.0	1.9	1.9	1.8	1.7	1.7	1.6	1.6	1.5	1.5	1.4
150 x 42	2.3	2.2	2.1	2.0	1.9	1.9	1.8	1.8	1.7	1.6	1.6	1.5
170 x 35	2.4	2.3	2.2	2.1	2.0	2.0	1.9	1.9	1.8	1.7	1.7	1.6
170 x 42	2.6	2.5	2.4	2.3	2.2	2.1	2.1	2.0	2.0	1.9	1.8	1.7
200 x 35	2.9	2.7	2.6	2.5	2.4	2.3	2.3	2.2	2.1	2.0	1.8	1.8
200 x 42	3.1	2.9	2.8	2.7	2.6	2.5	2.4	2.4	2.3	2.2	2.1	2.0
200 x 57	3.4	3.3	3.1	3.0	2.9	2.8	2.7	2.6	2.6	2.4	2.3	2.3
240 x 35	3.4	3.3	3.1	3.0	2.9	2.7	2.6	2.5	2.4	2.2	2.0	1.9
240 x 42	3.7	3.5	3.3	3.2	3.1	3.0	2.9	2.8	2.8	2.6	2.5	2.4
240 x 57	4.1	3.9	3.7	3.6	3.5	3.3	3.2	3.2	3.1	2.9	2.8	2.7
300 x 42	4.6	4.4	4.2	4.0	3.9	3.7	3.6	3.5	3.4	3.3	3.1	3.0
300 x 57	5.1	4.8	4.6	4.5	4.3	4.2	4.0	3.9	3.8	3.7	3.5	3.4
300 x 75	5.4	5.1	4.9	4.7	4.5	4.4	4.3	4.2	4.1	3.9	3.7	3.6
350 x 57	6.1	5.8	5.5	5.3	5.2	5.0	4.8	4.7	4.6	4.4	4.2	4.0
400 x 42	6.1	5.8	5.5	5.3	5.0	4.8	4.6	4.4	4.2	4.0	3.7	3.5
400 x 57	6.7	6.4	6.1	5.9	5.7	5.5	5.4	5.2	5.1	4.9	4.7	4.5
400 x 75	7.1	6.8	6.5	6.2	6.0	5.8	5.7	5.5	5.4	5.1	4.9	4.7
450 x 57	7.6	7.2	6.9	6.6	6.4	6.2	6.0	5.9	5.7	5.5	5.2	5.0
Maximum Continuous Span (m)												
150 x 35	2.9	2.7	2.6	2.5	2.4	2.3	2.3	2.2	2.1	2.0	1.9	1.8
150 x 42	3.1	2.9	2.8	2.7	2.6	2.5	2.4	2.4	2.3	2.2	2.1	2.0
170 x 35	3.3	3.1	3.0	2.8	2.7	2.6	2.6	2.5	2.4	2.3	2.1	2.0
170 x 42	3.5	3.3	3.2	3.1	2.9	2.9	2.8	2.7	2.6	2.5	2.4	2.3
200 x 35	3.8	3.6	3.5	3.3	3.2	3.1	3.0	2.9	2.8	2.6	2.5	2.3
200 x 42	4.1	3.9	3.7	3.6	3.5	3.4	3.2	3.2	3.1	2.9	2.8	2.7
200 x 57	4.6	4.4	4.2	4.0	3.9	3.7	3.6	3.5	3.4	3.3	3.1	3.0
240 x 35	4.6	4.4	4.1	3.9	3.8	3.5	3.4	3.3	3.2	3.0	2.8	2.6
240 x 42	4.9	4.7	4.5	4.3	4.2	4.0	3.9	3.8	3.7	3.5	3.4	3.1
240 x 57	5.5	5.2	5.0	4.8	4.6	4.5	4.3	4.2	4.1	3.9	3.8	3.6
300 x 42	6.1	5.8	5.6	5.3	5.1	4.9	4.7	4.5	4.4	4.2	3.9	3.7
300 x 57	6.8	6.5	6.2	6.0	5.8	5.6	5.4	5.3	5.1	4.9	4.7	4.5
300 x 75	7.2	6.9	6.6	6.3	6.1	5.9	5.7	5.6	5.4	5.2	5.0	4.8
350 x 57	8.2	7.8	7.4	7.2	6.9	6.7	6.5	6.3	6.2	5.9	5.6	5.3
400 x 42	7.0	6.7	6.3	6.0	5.8	5.7	5.5	5.3	5.1	4.8	4.6	4.4
400 x 57	9.0	8.6	8.2	7.9	7.7	7.4	7.1	6.9	6.7	6.3	5.9	5.7
400 x 75	9.5	9.1	8.7	8.4	8.1	7.8	7.6	7.4	7.2	6.9	6.6	6.4

Strutting Beams

Supporting Underpurlins only
For N3 wind classification

e-beam Section D X B (mm)	Sheet Roof								
	Roof Area Supported (m ²)								
	2	3	4	5	6	7	8	10	12
	Maximum Span (m)								
150 x 42#	4.0	3.7	3.2	2.9	2.7	2.5	2.3	2.1	NS
150 x 57	4.7	4.2	3.7	3.4	3.1	2.9	2.7	2.5	2.3
2/150 x 35#	5.0	4.4	3.9	3.6	3.3	3.1	2.9	2.6	2.4
170 x 42#	4.8	4.3	3.8	3.5	3.2	3.0	2.8	2.5	2.2
170 x 57	5.4	4.9	4.4	4.0	3.7	3.5	3.3	2.9	2.7
200 x 57#	6.4	6.0	5.5	5.0	4.7	4.4	4.1	3.7	3.4
2/200 x 35#	6.7	6.2	5.7	5.3	4.9	4.6	4.3	3.8	3.3
2/200 x 42#	7.0	6.5	6.1	5.7	5.4	5.1	4.8	4.4	4.0
240 x 57#	7.5	7.0	6.6	6.2	5.9	5.6	5.3	4.8	4.4
2/240 x 42#	7.9	7.5	7.1	6.8	6.5	6.3	6.1	5.6	5.2
300 x 57#	8.9	8.3	7.9	7.5	7.2	7.0	6.7	6.4	6.0
300 x 75#	9.1	8.6	8.2	7.8	7.5	7.3	7.0	6.7	6.3
2/300 x 42#	9.2	8.8	8.4	8.1	7.8	7.6	7.4	6.6	6.1
350 x 57#	10.0	9.5	9.1	8.7	8.4	8.2	7.9	7.5	7.1
400 x 57#	10.7	10.3	9.9	9.5	9.2	8.9	8.6	8.2	7.8
400 x 75#	10.9	10.5	10.1	9.8	9.5	9.2	9.0	8.5	8.2
450 x 57#	11.6	11.1	10.7	10.4	10.1	9.8	9.5	9.1	8.4

1. All sections with depth to breadth ratio exceeding three must be restrained against rollover at supports.
2. Sections marked with # must be laterally restrained at each strutting point - see AS 1684.
3. Multiple sections nail laminated as per AS 1684.
4. A minimum initial clearance of 25mm to ceiling framing members shall be provided at mid-span.
5. Bearing length at end supports to be not less than 70mm.
6. Beam ends may be chamfer cut to a minimum depth of 90mm or D/3, whichever is greater.
7. NS signifies section size unlikely to be suitable.

Strutting Beams

Supporting Underpurlins only
For N3 wind classification

e-beam Section D X B (mm)	Tile Roof								
	Roof Area Supported (m ²)								
	2	3	4	5	6	7	8	10	12
	Maximum Span (m)								
150 x 42#	3.0	2.5	2.2	NS	NS	NS	NS	NS	NS
150 x 57	3.5	2.9	2.5	2.3	2.1	NS	NS	NS	NS
2/150 x 35#	3.7	3.1	2.7	2.4	2.2	2.1	NS	NS	NS
170 x 42#	3.6	3.0	2.6	2.3	2.1	2.0	1.9	NS	NS
170 x 57	4.1	3.5	3.0	2.7	2.5	2.3	2.2	2.0	NS
200 x 57#	5.2	4.4	3.8	3.5	3.2	3.0	2.8	2.5	2.3
2/200 x 35#	5.4	4.6	4.1	3.7	3.4	3.2	3.0	2.7	2.4
2/200 x 42#	5.9	5.1	4.5	4.1	3.8	3.5	3.3	3.0	2.7
240 x 57#	6.3	5.6	5.0	4.5	4.1	3.9	3.6	3.3	3.0
2/240 x 42#	6.9	6.3	5.7	5.3	4.9	4.5	4.3	3.9	3.5
300 x 57#	7.7	7.0	6.5	6.1	5.7	5.3	5.0	4.5	4.1
300 x 75#	7.9	7.3	6.8	6.4	6.1	5.7	5.4	4.9	4.5
2/300 x 42#	8.2	7.6	7.1	6.7	6.4	6.1	5.8	5.3	4.9
350 x 57#	8.9	8.2	7.6	7.2	6.8	6.6	6.3	5.9	5.4
400 x 57#	9.6	8.9	8.3	7.9	7.5	7.2	7.0	6.5	6.2
400 x 75#	9.9	9.2	8.7	8.2	7.9	7.6	7.3	6.9	6.5
450 x 57#	10.5	9.8	9.2	8.8	8.4	8.0	7.8	7.3	6.9

1. All sections with depth to breadth ratio exceeding three must be restrained against rollover at supports.
2. Sections marked with # must be laterally restrained at each strutting point - see AS 1684.
3. Multiple sections nail laminated as per AS 1684.
4. A minimum initial clearance of 25mm to ceiling framing members shall be provided at mid-span.
5. Bearing length at end supports to be not less than 70mm.
6. Beam ends may be chamfer cut to a minimum depth of 90mm or D/3, whichever is greater.
7. NS signifies section size unlikely to be suitable.

Strutting-counter Beams

Supporting Underpurlins and Hanging Beams For N3 wind classification

e-beam Section D X B (mm)	Average Hanging Beam Span (m)											
	2.4						4.2					
	Roof Area Supported (m ²)											
	2	4	6	8	10	12	2	4	6	8	10	12
Maximum Span (m) for Sheet Roof & Ceiling												
170 x 57	4.0	3.6	3.3	3.0	2.7	2.6	3.7	3.3	3.1	2.8	2.6	2.5
2/170 x 35	4.1	3.8	3.5	3.2	2.9	2.7	3.8	3.5	3.2	3.0	2.8	2.6
2/170 x 42	4.3	4.0	3.7	3.5	3.2	3.0	4.0	3.7	3.5	3.3	3.1	2.9
200 x 57	4.5	4.2	3.9	3.7	3.4	3.2	4.2	3.9	3.7	3.5	3.2	3.1
2/200 x 35	4.7	4.3	4.0	3.8	3.6	3.4	4.3	4.0	3.8	3.6	3.4	3.2
2/200 x 42	4.9	4.5	4.3	4.0	3.8	3.7	4.5	4.3	4.0	3.9	3.7	3.6
240 x 57	5.2	4.8	4.5	4.3	4.1	3.9	4.8	4.5	4.3	4.1	3.9	3.8
2/240 x 42	5.6	5.2	5.0	4.7	4.5	4.3	5.1	4.9	4.7	4.5	4.3	4.2
300 x 57	6.1	5.7	5.4	5.2	5.0	4.8	5.6	5.3	5.1	4.9	4.7	4.6
300 x 75	6.3	6.0	5.7	5.4	5.2	5.0	5.8	5.5	5.3	5.1	5.0	4.8
2/300 x 42	6.5	6.2	5.9	5.7	5.5	5.3	6.0	5.8	5.6	5.4	5.2	5.1
350 x 57	6.9	6.6	6.3	6.0	5.8	5.6	6.3	6.1	5.9	5.7	5.5	5.4
400 x 57	7.4	7.1	6.8	6.6	6.3	6.1	6.8	6.6	6.4	6.2	6.0	5.8
400 x 75	7.7	7.4	7.1	6.8	6.6	6.4	7.1	6.8	6.6	6.4	6.3	6.1
2/400 x 42	7.9	7.6	7.3	7.1	6.9	6.7	7.3	7.1	6.9	6.7	6.5	6.4
450 x 57	8.1	7.7	7.4	7.2	7.0	6.8	7.4	7.2	7.0	6.8	6.6	6.4
2/450 x 57	9.0	8.8	8.5	8.3	8.1	7.9	8.4	8.2	8.0	7.9	7.7	7.5
Maximum Span (m) for Tile Roof and Ceiling												
170 x 57	3.5	2.8	2.4	2.1	1.9	NS	3.2	2.7	2.3	2.1	1.9	NS
2/170 x 35	3.7	3.0	2.6	2.3	2.0	1.9	3.4	2.8	2.5	2.2	2.0	1.9
2/170 x 42	3.9	3.3	2.8	2.5	2.3	2.1	3.7	3.1	2.7	2.4	2.2	2.1
200 x 57	4.1	3.5	3.0	2.7	2.4	2.2	3.8	3.3	2.9	2.6	2.4	2.2
2/200 x 35	4.2	3.7	3.2	2.8	2.6	2.4	4.0	3.5	3.1	2.8	2.5	2.3
2/200 x 42	4.4	3.9	3.5	3.1	2.9	2.6	4.2	3.8	3.4	3.1	2.8	2.6
240 x 57	4.7	4.1	3.8	3.4	3.1	2.9	4.4	4.0	3.7	3.3	3.1	2.8
2/240 x 42	5.1	4.6	4.2	3.9	3.7	3.4	4.8	4.4	4.1	3.8	3.6	3.3
300 x 57	5.6	5.0	4.6	4.3	4.1	3.9	5.3	4.8	4.5	4.2	4.0	3.8
300 x 75	5.9	5.3	4.8	4.5	4.3	4.1	5.5	5.0	4.7	4.4	4.2	4.0
2/300 x 42	6.1	5.5	5.1	4.8	4.5	4.3	5.7	5.3	4.9	4.6	4.4	4.2
350 x 57	6.5	5.9	5.4	5.1	4.8	4.6	6.0	5.6	5.2	4.9	4.7	4.5
400 x 57	7.0	6.4	5.9	5.6	5.3	5.0	6.5	6.1	5.7	5.4	5.1	4.9
400 x 75	7.3	6.7	6.2	5.9	5.6	5.3	6.8	6.3	6.0	5.7	5.4	5.2
2/400 x 42	7.5	7.0	6.5	6.1	5.8	4.8	7.0	6.6	6.2	5.9	5.0	4.7
450 x 57	7.6	7.0	6.6	6.2	5.9	5.6	7.1	6.7	6.3	6.0	5.7	5.5
2/450 x 57	8.7	8.2	7.7	7.4	7.1	6.8	8.1	7.7	7.4	7.1	6.9	6.6

1. Average hanging beam span = $(H1 + H2) / 2$, where H1 and H2 are the spans of the hanging beams on each side of the Strutting-Counter beam.
2. All sections with depth to breadth ratio exceeding three must be restrained against rollover at supports.
3. Multiple sections nail laminated as per AS 1684.
4. Bearing length at end supports to be not less than 70mm.
5. Beam ends may be chamfer cut to a minimum depth of 90mm or D/3, whichever is greater.
6. NS signifies section size unlikely to be suitable.

Strutting - Hanging Beams

Supporting Underpurlins and Ceiling Joists For N3 wind classification

e-beam Section D X B (mm)	Ceiling Load Width (CLW) (m)												
	2.4				3.0				3.6				
	Roof Load Width (RLW) for Underpurlin (m)												
	1.8	2.4	3.0	3.6	1.8	2.4	3.0	3.6	1.8	2.4	3.0	3.6	4.2
	Maximum Span for Sheet Roof & Ceiling (m)												
170 x 57	3.6	3.5	3.3	3.2	3.5	3.3	3.2	3.1	3.3	3.2	3.1	3.0	2.9
2/170 x 35	3.7	3.6	3.5	3.3	3.6	3.5	3.3	3.2	3.5	3.3	3.2	3.1	3.0
2/170 x 42	3.9	3.8	3.7	3.6	3.8	3.7	3.6	3.5	3.7	3.6	3.5	3.3	3.3
200 x 57	4.1	3.9	3.8	3.7	3.9	3.8	3.7	3.6	3.8	3.7	3.6	3.5	3.4
2/200 x 35	4.2	4.1	3.9	3.8	4.1	3.9	3.8	3.7	3.9	3.8	3.7	3.6	3.6
2/200 x 42	4.4	4.3	4.1	4.0	4.3	4.1	4.0	3.9	4.1	4.0	3.9	3.8	3.8
240 x 57	4.7	4.5	4.4	4.2	4.5	4.4	4.2	4.1	4.4	4.2	4.1	4.0	4.0
2/240 x 42	5.0	4.9	4.7	4.6	4.9	4.7	4.6	4.5	4.7	4.6	4.5	4.4	4.3
300 x 57	5.5	5.3	5.1	5.0	5.3	5.1	5.0	4.9	5.1	5.0	4.9	4.8	4.7
300 x 75	5.7	5.5	5.3	5.2	5.5	5.3	5.2	5.1	5.3	5.2	5.1	5.0	4.9
2/300 x 42	5.9	5.7	5.5	5.4	5.7	5.6	5.4	5.3	5.5	5.4	5.3	5.2	5.1
350 x 57	6.2	6.0	5.8	5.7	6.0	5.9	5.7	5.6	5.8	5.7	5.6	5.4	5.3
400 x 57	6.7	6.5	6.3	6.1	6.5	6.3	6.2	6.0	6.3	6.1	6.0	5.9	5.8
400 x 75	7.0	6.7	6.6	6.4	6.8	6.6	6.4	6.2	6.6	6.4	6.2	6.1	6.0
2/400 x 42	7.2	7.0	6.8	6.6	7.0	6.8	6.6	6.5	6.8	6.6	6.5	6.4	6.2
450 x 57	7.3	7.1	6.9	6.7	7.1	6.9	6.7	6.5	6.9	6.7	6.5	6.4	6.3
2/450 x 57	8.3	8.1	7.9	7.7	8.1	7.9	7.7	7.6	7.9	7.7	7.6	7.4	7.3
Maximum Span for Tile Roof & Ceiling (m)													
170 x 57	3.1	2.9	2.7	2.6	3.0	2.8	2.7	2.6	2.9	2.7	2.6	2.5	2.4
2/170 x 35	3.2	3.0	2.8	2.7	3.1	2.9	2.8	2.7	3.0	2.9	2.7	2.6	2.5
2/170 x 42	3.5	3.2	3.1	2.9	3.4	3.2	3.0	2.9	3.3	3.1	2.9	2.8	2.7
200 x 57	3.6	3.4	3.2	3.0	3.5	3.3	3.1	3.0	3.4	3.2	3.1	2.9	2.8
2/200 x 35	3.7	3.5	3.3	3.2	3.7	3.4	3.3	3.1	3.6	3.4	3.2	3.1	3.0
2/200 x 42	3.9	3.7	3.6	3.4	3.8	3.7	3.5	3.4	3.8	3.6	3.4	3.3	3.2
240 x 57	4.1	3.9	3.8	3.6	4.0	3.9	3.7	3.6	4.0	3.8	3.7	3.5	3.4
2/240 x 42	4.5	4.3	4.1	4.0	4.4	4.2	4.0	3.9	4.3	4.1	4.0	3.9	3.8
300 x 57	4.9	4.6	4.4	4.3	4.8	4.6	4.4	4.2	4.7	4.5	4.3	4.2	4.1
300 x 75	5.1	4.8	4.6	4.5	5.0	4.7	4.6	4.4	4.9	4.7	4.5	4.4	4.2
2/300 x 42	5.3	5.0	4.8	4.7	5.2	4.9	4.8	4.6	5.1	4.9	4.7	4.5	4.4
350 x 57	5.6	5.3	5.1	4.9	5.4	5.2	5.0	4.8	5.3	5.1	4.9	4.8	4.6
400 x 57	6.0	5.7	5.5	5.3	5.9	5.6	5.4	5.2	5.8	5.5	5.3	5.2	5.0
400 x 75	6.2	5.9	5.7	5.5	6.1	5.8	5.6	5.5	6.0	5.7	5.5	5.4	5.2
2/400 x 42	6.5	6.2	6.0	5.8	6.4	6.1	5.9	5.7	6.2	6.0	5.8	5.6	5.5
450 x 57	6.5	6.2	6.0	5.8	6.4	6.1	5.9	5.7	6.3	6.0	5.8	5.6	5.5
2/450 x 57	7.6	7.2	7.0	6.8	7.4	7.1	6.9	6.7	7.3	7.0	6.8	6.6	6.4

1. All sections with depth to breadth ratio exceeding three must be restrained against rollover at supports.
2. RLW for underpurlin is the average of the rafter spans on each side of the underpurlin supported by the Strutting-Hanging beam.
3. Underpurlin span assumed to be one-half the Strutting-Hanging beam span.
4. CLW is the average of the ceiling joist spans on each side of the Strutting-Hanging beam.
5. Multiple sections nail laminated as per AS 1684.
6. Bearing length at end supports to be not less than 70mm.
7. Beam ends may be chamfer cut to a minimum depth of 90mm or D/3, whichever is greater.

Counter Beams

Supporting Hanging Beams

e-beam Section D X B (mm)	Ceiling Load Width 'CLW' (m)							
	2.4	3.0	3.6	4.2	4.8	5.4	6.0	6.6
	Maximum Span (m)							
150 x 35	3.4	3.2	3.0	2.9	2.8	2.7	2.6	2.5
150 x 42	3.7	3.4	3.3	3.1	3.0	2.9	2.8	2.7
170 x 35	3.9	3.6	3.4	3.3	3.1	3.0	2.8	2.7
170 x 42	4.2	3.9	3.7	3.5	3.4	3.2	3.1	3.0
200 x 35	4.4	4.1	3.8	3.6	3.5	3.2	3.1	3.0
200 x 42	4.8	4.5	4.3	4.1	3.9	3.8	3.7	3.6
200 x 57	5.1	4.9	4.7	4.5	4.4	4.2	4.1	4.0
240 x 35	4.8	4.4	4.1	4.0	3.8	3.6	3.5	3.4
240 x 42	5.4	5.2	5.0	4.8	4.6	4.3	4.2	4.1
240 x 57	5.8	5.6	5.3	5.2	5.0	4.9	4.8	4.7
300 x 42	6.4	6.0	5.6	5.3	5.1	4.8	4.7	4.6
300 x 57	6.8	6.5	6.3	6.1	5.9	5.7	5.6	5.5
300 x 75	7.0	6.7	6.5	6.3	6.1	6.0	5.8	5.7
350 x 57	7.7	7.4	7.1	6.9	6.7	6.5	6.4	6.3
400 x 42	6.9	6.4	6.1	5.7	5.5	5.3	5.1	5.0
400 x 57	8.3	7.9	7.7	7.4	7.2	7.1	6.9	6.8
400 x 75	8.5	8.2	7.9	7.7	7.5	7.3	7.2	7.0
450 x 57	8.9	8.6	8.3	8.1	7.9	7.7	7.4	7.2

Verandah Beams

For N3 wind classification

e-beam Section D X B (mm)	Roof Mass kg/m ²	Single Span						Continuous Span							
		Roof Load Width 'RLW' (m)													
		0.9	1.2	1.5	1.8	2.1	2.4	2.7	0.9	1.2	1.5	1.8	2.1	2.4	2.7
		Maximum Span (m)													
130 x 35	10	3.6	3.3	3.1	2.9	2.8	2.7	2.6	4.0	3.9	3.7	3.4	3.2	3.0	2.8
	20	3.3	3.0	2.8	2.7	2.5	2.5	2.4	4.0	3.9	3.7	3.4	3.2	3.0	2.9
	40	2.7	2.5	2.4	2.3	2.1	1.9	1.9	3.6	3.3	3.0	2.9	2.7	2.6	2.5
	75	2.3	2.0	1.9	1.7	1.6	1.6	1.5	3.0	2.7	2.5	2.4	2.2	2.1	2.1
	90	2.1	1.9	1.8	1.7	1.6	1.5	1.5	2.8	2.6	2.4	2.2	2.1	2.0	1.9
130 x 42	10	3.9	3.5	3.3	3.1	2.9	2.9	2.8	4.2	4.2	4.1	3.8	3.5	3.3	3.1
	20	3.5	3.2	3.0	2.8	2.7	2.6	2.5	4.2	4.2	4.0	3.7	3.5	3.4	3.2
	40	2.9	2.7	2.5	2.4	2.3	2.2	2.1	3.9	3.5	3.3	3.1	2.9	2.8	2.7
	75	2.4	2.2	2.0	1.9	1.8	1.7	1.6	3.2	2.9	2.7	2.5	2.4	2.3	2.2
	90	2.3	2.1	1.9	1.7	1.7	1.6	1.6	3.1	2.8	2.6	2.4	2.3	2.2	2.1
130 x 57	10	4.2	4.0	3.7	3.4	3.3	3.2	3.0	5.1	5.0	4.8	4.4	4.2	4.0	3.7
	20	3.8	3.5	3.3	3.1	2.9	2.8	2.7	4.9	4.5	4.3	4.1	3.9	3.7	3.6
	40	3.2	2.9	2.8	2.6	2.5	2.4	2.4	4.2	3.9	3.7	3.4	3.2	3.1	3.0
	75	2.7	2.4	2.3	2.1	2.0	1.9	1.8	3.6	3.2	3.0	2.8	2.7	2.6	2.5
	90	2.5	2.3	2.1	2.0	1.9	1.8	1.7	3.4	3.1	2.9	2.7	2.5	2.4	2.4
150 x 35	10	4.1	3.8	3.5	3.3	3.2	3.0	2.9	5.0	4.8	4.2	3.9	3.6	3.4	3.2
	20	3.8	3.4	3.2	3.0	2.8	2.7	2.7	4.8	4.4	4.2	4.0	3.7	3.4	3.3
	40	3.1	2.9	2.7	2.6	2.4	2.4	2.3	4.1	3.8	3.5	3.3	3.1	3.0	2.9
	75	2.6	2.4	2.2	2.0	1.9	1.8	1.7	3.4	3.1	2.9	2.7	2.6	2.5	2.4
	90	2.5	2.2	2.0	1.9	1.8	1.7	1.6	3.2	3.0	2.7	2.6	2.5	2.4	2.2
150 x 42	10	4.4	4.1	3.8	3.5	3.4	3.3	3.1	5.2	5.1	4.9	4.5	4.1	3.8	3.5
	20	4.0	3.6	3.4	3.2	3.0	2.9	2.8	5.0	4.7	4.4	4.2	4.1	3.9	3.7
	40	3.3	3.0	2.8	2.7	2.6	2.5	2.4	4.3	4.1	3.8	3.6	3.4	3.2	3.1
	75	2.8	2.5	2.4	2.2	2.1	2.0	1.9	3.7	3.4	3.1	3.0	2.8	2.7	2.6
	90	2.6	2.4	2.2	2.1	2.0	1.8	1.8	3.6	3.2	3.0	2.8	2.6	2.5	2.4
150 x 57	10	4.8	4.6	4.3	4.0	3.8	3.6	3.5	5.7	5.5	5.3	5.1	4.9	4.7	4.3
	20	4.3	4.0	3.8	3.5	3.3	3.2	3.0	5.3	5.0	4.8	4.5	4.4	4.2	4.1
	40	3.7	3.3	3.1	3.0	2.8	2.7	2.6	4.7	4.4	4.2	3.9	3.7	3.6	3.4
	75	3.1	2.8	2.6	2.5	2.3	2.2	2.2	4.1	3.7	3.5	3.3	3.1	3.0	2.9
	90	2.9	2.6	2.5	2.4	2.2	2.1	2.0	3.9	3.6	3.3	3.1	3.0	2.8	2.7
170 x 35	10	4.5	4.4	4.0	3.8	3.5	3.4	3.2	5.4	5.1	4.8	4.3	4.0	3.7	3.5
	20	4.2	3.8	3.5	3.3	3.2	3.0	2.9	5.2	4.9	4.6	4.4	4.1	3.9	3.6
	40	3.5	3.2	3.0	2.8	2.7	2.6	2.5	4.5	4.2	4.0	3.7	3.6	3.4	3.2
	75	2.9	2.7	2.5	2.3	2.2	2.1	2.0	3.9	3.6	3.3	3.1	3.0	2.8	2.7
	90	2.8	2.5	2.4	2.2	2.1	1.9	1.9	3.7	3.3	3.1	2.9	2.8	2.6	2.5
170 x 42	10	4.9	4.6	4.4	4.1	3.9	3.7	3.5	5.7	5.6	5.4	5.1	4.8	4.4	4.1
	20	4.4	4.1	3.8	3.6	3.4	3.2	3.1	5.5	5.1	4.9	4.6	4.4	4.3	4.1
	40	3.7	3.4	3.1	3.0	2.9	2.7	2.6	4.8	4.4	4.2	4.0	3.8	3.6	3.5
	75	3.1	2.9	2.7	2.5	2.4	2.3	2.2	4.1	3.8	3.6	3.3	3.2	3.0	2.9
	90	3.0	2.7	2.5	2.4	2.2	2.1	2.0	4.0	3.6	3.3	3.2	3.0	2.9	2.7

Verandah Beams continued

For N3 wind classification

e-beam Section D X B (mm)	Roof Mass kg/m ²	Single Span							Continuous Span						
		Roof Load Width 'RLW' (m)													
		0.9	1.2	1.5	1.8	2.1	2.4	2.7	0.9	1.2	1.5	1.8	2.1	2.4	2.7
		Maximum Span (m)													
170 x 57	10	5.2	4.9	4.7	4.5	4.3	4.1	4.0	6.2	6.1	5.8	5.6	5.4	5.2	5.0
	20	4.7	4.4	4.2	4.0	3.8	3.6	3.4	5.8	5.5	5.2	5.0	4.8	4.6	4.5
	40	4.1	3.8	3.5	3.3	3.1	3.0	2.9	5.1	4.8	4.5	4.3	4.2	4.0	3.9
	75	3.5	3.2	2.9	2.7	2.7	2.5	2.4	4.5	4.2	4.0	3.7	3.6	3.4	3.2
	90	3.3	3.0	2.8	2.6	2.5	2.4	2.3	4.3	4.0	3.7	3.6	3.3	3.2	3.1
200 x 35	10	5.3	5.0	4.7	4.4	3.9	3.6	3.4	6.1	5.7	5.2	4.9	4.6	4.3	4.1
	20	4.8	4.4	4.2	4.0	3.7	3.6	3.4	5.9	5.5	5.2	5.0	4.8	4.4	4.2
	40	4.1	3.7	3.5	3.3	3.1	3.0	2.8	5.1	4.8	4.5	4.3	4.1	4.0	3.8
	75	3.4	3.1	2.9	2.7	2.6	2.5	2.4	4.4	4.1	3.9	3.7	3.5	3.3	3.2
	90	3.2	2.9	2.7	2.6	2.5	2.3	2.3	4.2	4.0	3.7	3.4	3.3	3.1	3.0
200 x 42	10	5.4	5.2	4.9	4.8	4.5	4.3	4.2	6.5	6.3	6.0	5.7	5.3	5.1	4.9
	20	4.9	4.6	4.4	4.2	4.0	3.8	3.6	6.1	5.7	5.5	5.2	5.0	4.9	4.7
	40	4.3	4.0	3.7	3.5	3.3	3.1	3.0	5.3	5.0	4.8	4.5	4.3	4.2	4.1
	75	3.7	3.4	3.1	2.9	2.8	2.6	2.5	4.7	4.4	4.1	3.9	3.7	3.6	3.4
	90	3.5	3.2	2.9	2.8	2.6	2.5	2.4	4.5	4.2	4.0	3.7	3.6	3.3	3.2
200 x 57	10	5.8	5.5	5.2	5.0	4.9	4.7	4.6	7.2	6.8	6.5	6.3	6.0	5.8	5.6
	20	5.2	5.0	4.8	4.5	4.3	4.2	4.0	6.5	6.2	5.9	5.6	5.4	5.2	5.1
	40	4.6	4.4	4.1	3.9	3.7	3.5	3.4	5.7	5.4	5.1	4.9	4.8	4.5	4.4
	75	4.0	3.7	3.5	3.2	3.1	2.9	2.8	5.0	4.7	4.4	4.3	4.1	4.0	3.8
	90	3.9	3.5	3.3	3.0	2.9	2.8	2.7	4.8	4.5	4.3	4.1	3.9	3.7	3.6
240 x 42	10	6.2	5.8	5.6	5.3	5.1	5.0	4.8	7.7	7.3	6.9	6.5	6.0	5.7	5.5
	20	5.5	5.2	5.0	4.8	4.6	4.5	4.3	6.9	6.5	6.2	6.0	5.7	5.5	5.3
	40	4.9	4.6	4.3	4.2	4.0	3.8	3.6	6.1	5.7	5.4	5.2	5.0	4.8	4.7
	75	4.3	4.0	3.8	3.5	3.3	3.2	3.1	5.3	5.0	4.7	4.5	4.3	4.2	4.1
	90	4.1	3.8	3.5	3.3	3.1	3.0	2.9	5.1	4.8	4.5	4.3	4.2	4.0	3.9
240 x 57	10	6.5	6.1	5.9	5.7	5.5	5.3	5.2	8.1	7.7	7.4	7.2	6.8	6.6	6.4
	20	5.9	5.6	5.4	5.1	5.0	4.8	4.6	7.4	7.0	6.6	6.4	6.2	6.0	5.8
	40	5.3	5.0	4.7	4.5	4.3	4.2	4.1	6.5	6.2	5.8	5.6	5.4	5.2	5.1
	75	4.6	4.3	4.1	3.9	3.7	3.6	3.4	5.7	5.4	5.1	4.9	4.7	4.5	4.4
	90	4.4	4.2	3.9	3.7	3.5	3.3	3.2	5.5	5.2	4.9	4.7	4.5	4.4	4.2
300 x 42	10	7.2	6.8	6.5	6.2	6.0	5.8	5.6	8.9	8.5	8.0	7.5	7.1	6.7	6.3
	20	6.5	6.1	5.8	5.6	5.4	5.2	5.0	8.1	7.6	7.3	7.0	6.7	6.5	6.3
	40	5.7	5.4	5.1	4.9	4.7	4.6	4.4	7.2	6.7	6.4	6.1	5.9	5.7	5.5
	75	5.0	4.7	4.5	4.2	4.1	4.0	3.8	6.3	5.9	5.5	5.3	5.1	4.9	4.8
	90	4.8	4.5	4.3	4.1	3.9	3.7	3.6	6.0	5.6	5.3	5.1	4.9	4.8	4.6
300 x 57	10	7.5	7.2	6.9	6.6	6.4	6.2	6.0	9.3	8.9	8.5	8.3	8.0	7.7	7.5
	20	6.9	6.5	6.2	6.0	5.8	5.6	5.4	8.5	8.1	7.7	7.4	7.2	7.0	6.7
	40	6.1	5.8	5.5	5.3	5.1	5.0	4.8	7.6	7.2	6.8	6.6	6.4	6.2	6.0
	75	5.4	5.1	4.8	4.6	4.4	4.3	4.2	6.7	6.3	6.0	5.7	5.5	5.3	5.2
	90	5.2	4.9	4.6	4.5	4.2	4.1	4.0	6.5	6.1	5.8	5.5	5.3	5.1	5.0

1. Bearing length at end supports to be not less than 30 mm and at intermediate supports for continuous span at least 70mm.

Verandah Beams

For N3 wind classification

e-beam Section D X B (mm)	Roof Mass kg/m ²	Single Span							Continuous Span						
		Roof Load Width 'RLW' (m)													
		0.9	1.2	1.5	1.8	2.1	2.4	2.7	0.9	1.2	1.5	1.8	2.1	2.4	2.7
		Maximum Span (m)													
130 x 35	10	3.7	3.5	3.3	3.1	2.9	2.8	2.7	4.0	3.9	3.9	3.8	3.8	3.6	3.5
	20	3.3	3.0	2.8	2.7	2.5	2.5	2.4	4.0	3.9	3.7	3.5	3.3	3.1	3.0
	40	2.7	2.5	2.4	2.3	2.1	1.9	1.9	3.6	3.3	3.0	2.9	2.7	2.6	2.5
	75	2.3	2.0	1.9	1.7	1.6	1.6	1.5	3.0	2.7	2.5	2.4	2.2	2.1	2.1
	90	2.1	1.9	1.8	1.7	1.6	1.5	1.5	2.8	2.6	2.4	2.2	2.1	2.0	1.9
130 x 42	10	3.9	3.8	3.5	3.3	3.1	2.9	2.8	4.2	4.2	4.1	4.0	4.0	3.9	3.7
	20	3.5	3.2	3.0	2.8	2.7	2.6	2.5	4.2	4.2	4.0	3.7	3.5	3.4	3.2
	40	2.9	2.7	2.5	2.4	2.3	2.2	2.1	3.9	3.5	3.3	3.1	2.9	2.8	2.7
	75	2.4	2.2	2.0	1.9	1.8	1.7	1.6	3.2	2.9	2.7	2.5	2.4	2.3	2.2
	90	2.3	2.1	1.9	1.7	1.7	1.6	1.6	3.1	2.8	2.6	2.4	2.3	2.2	2.1
130 x 57	10	4.2	4.1	3.8	3.6	3.4	3.2	3.1	5.1	5.0	4.8	4.4	4.4	4.2	4.1
	20	3.8	3.5	3.3	3.1	2.9	2.8	2.7	4.9	4.5	4.3	4.1	3.9	3.7	3.6
	40	3.2	2.9	2.8	2.6	2.5	2.4	2.4	4.2	3.9	3.7	3.4	3.2	3.1	3.0
	75	2.7	2.4	2.3	2.1	2.0	1.9	1.8	3.6	3.2	3.0	2.8	2.7	2.6	2.5
	90	2.5	2.3	2.1	2.0	1.9	1.8	1.7	3.4	3.1	2.9	2.7	2.5	2.4	2.4
150 x 35	10	4.1	4.0	3.7	3.5	3.3	3.1	3.0	5.0	4.9	4.3	4.3	4.2	4.1	3.9
	20	3.8	3.4	3.2	3.0	2.8	2.7	2.7	4.8	4.4	4.2	4.0	3.8	3.6	3.4
	40	3.1	2.9	2.7	2.6	2.4	2.4	2.3	4.1	3.8	3.5	3.3	3.1	3.0	2.9
	75	2.6	2.4	2.2	2.0	1.9	1.8	1.7	3.4	3.1	2.9	2.7	2.6	2.5	2.4
	90	2.5	2.2	2.0	1.9	1.8	1.7	1.6	3.2	3.0	2.7	2.6	2.5	2.4	2.2
150 x 42	10	4.4	4.2	4.0	3.8	3.5	3.3	3.2	5.2	5.1	4.9	4.6	4.5	4.3	4.2
	20	4.0	3.6	3.4	3.2	3.0	2.9	2.8	5.0	4.7	4.4	4.2	4.1	3.9	3.7
	40	3.3	3.0	2.8	2.7	2.6	2.5	2.4	4.3	4.1	3.8	3.6	3.4	3.2	3.1
	75	2.8	2.5	2.4	2.2	2.1	2.0	1.9	3.7	3.4	3.1	3.0	2.8	2.7	2.6
	90	2.6	2.4	2.2	2.1	2.0	1.8	1.8	3.6	3.2	3.0	2.8	2.6	2.5	2.4
150 x 57	10	4.8	4.6	4.3	4.1	3.9	3.7	3.6	5.7	5.5	5.3	5.1	4.9	4.8	4.6
	20	4.3	4.0	3.8	3.5	3.3	3.2	3.0	5.3	5.0	4.8	4.5	4.4	4.2	4.1
	40	3.7	3.3	3.1	3.0	2.8	2.7	2.6	4.7	4.4	4.2	3.9	3.7	3.6	3.4
	75	3.1	2.8	2.6	2.5	2.3	2.2	2.2	4.1	3.7	3.5	3.3	3.1	3.0	2.9
	90	2.9	2.6	2.5	2.4	2.2	2.1	2.0	3.9	3.6	3.3	3.1	3.0	2.8	2.7
170 x 35	10	4.5	4.4	4.2	4.0	3.8	3.5	3.4	5.4	5.3	5.1	4.9	4.7	4.5	4.4
	20	4.2	3.8	3.5	3.3	3.2	3.0	2.9	5.2	4.9	4.6	4.4	4.2	4.1	3.9
	40	3.5	3.2	3.0	2.8	2.7	2.6	2.5	4.5	4.2	4.0	3.7	3.6	3.4	3.2
	75	2.9	2.7	2.5	2.3	2.2	2.1	2.0	3.9	3.6	3.3	3.1	3.0	2.8	2.7
	90	2.8	2.5	2.4	2.2	2.1	1.9	1.9	3.7	3.3	3.1	2.9	2.8	2.6	2.5

Verandah Beams continued

For N3 wind classification

e-beam Section D X B (mm)	Roof Mass kg/m ²	Single Span							Continuous Span						
		Roof Load Width 'RLW' (m)													
		0.9	1.2	1.5	1.8	2.1	2.4	2.7	0.9	1.2	1.5	1.8	2.1	2.4	2.7
		Maximum Span (m)													
170 x 42	10	4.9	4.6	4.4	4.2	4.0	3.8	3.6	5.7	5.6	5.4	5.1	4.9	4.8	4.7
	20	4.4	4.1	3.8	3.6	3.4	3.2	3.1	5.5	5.1	4.9	4.6	4.4	4.3	4.1
	40	3.7	3.4	3.1	3.0	2.9	2.7	2.6	4.8	4.4	4.2	4.0	3.8	3.6	3.5
	75	3.1	2.9	2.7	2.5	2.4	2.3	2.2	4.1	3.8	3.6	3.3	3.2	3.0	2.9
	90	3.0	2.7	2.5	2.4	2.2	2.1	2.0	4.0	3.6	3.3	3.2	3.0	2.9	2.7
170 x 57	10	5.2	4.9	4.7	4.5	4.3	4.1	4.0	6.2	6.1	5.8	5.6	5.4	5.2	5.0
	20	4.7	4.4	4.2	4.0	3.8	3.6	3.4	5.8	5.5	5.2	5.0	4.8	4.6	4.5
	40	4.1	3.8	3.5	3.3	3.1	3.0	2.9	5.1	4.8	4.5	4.3	4.2	4.0	3.9
	75	3.5	3.2	2.9	2.7	2.7	2.5	2.4	4.5	4.2	4.0	3.7	3.6	3.4	3.2
	90	3.3	3.0	2.8	2.6	2.5	2.4	2.3	4.3	4.0	3.7	3.6	3.3	3.2	3.1
200 x 35	10	5.3	5.0	4.7	4.5	4.3	4.1	4.0	6.1	6.0	5.7	5.5	5.3	5.1	5.0
	20	4.8	4.4	4.2	4.0	3.7	3.6	3.4	5.9	5.5	5.2	5.0	4.8	4.6	4.4
	40	4.1	3.7	3.5	3.3	3.1	3.0	2.8	5.1	4.8	4.5	4.3	4.1	4.0	3.8
	75	3.4	3.1	2.9	2.7	2.6	2.5	2.4	4.4	4.1	3.9	3.7	3.5	3.3	3.2
	90	3.2	2.9	2.7	2.6	2.5	2.3	2.3	4.2	4.0	3.7	3.4	3.3	3.1	3.0
200 x 42	10	5.4	5.2	4.9	4.8	4.5	4.3	4.2	6.5	6.3	6.0	5.8	5.5	5.4	5.2
	20	4.9	4.6	4.4	4.2	4.0	3.8	3.6	6.1	5.7	5.5	5.2	5.0	4.9	4.7
	40	4.3	4.0	3.7	3.5	3.3	3.1	3.0	5.3	5.0	4.8	4.5	4.3	4.2	4.1
	75	3.7	3.4	3.1	2.9	2.8	2.6	2.5	4.7	4.4	4.1	3.9	3.7	3.6	3.4
	90	3.5	3.2	2.9	2.8	2.6	2.5	2.4	4.5	4.2	4.0	3.7	3.6	3.3	3.2
200 x 57	10	5.8	5.5	5.2	5.0	4.9	4.7	4.6	7.2	6.8	6.5	6.3	6.0	5.8	5.6
	20	5.2	5.0	4.8	4.5	4.3	4.2	4.0	6.5	6.2	5.9	5.6	5.4	5.2	5.1
	40	4.6	4.4	4.1	3.9	3.7	3.5	3.4	5.7	5.4	5.1	4.9	4.8	4.5	4.4
	75	4.0	3.7	3.5	3.2	3.1	2.9	2.8	5.0	4.7	4.4	4.3	4.1	4.0	3.8
	90	3.9	3.5	3.3	3.0	2.9	2.8	2.7	4.8	4.5	4.3	4.1	3.9	3.7	3.6
240 x 42	10	6.2	5.8	5.6	5.3	5.1	5.0	4.8	7.7	7.3	6.9	6.6	6.4	6.2	6.0
	20	5.5	5.2	5.0	4.8	4.6	4.5	4.3	6.9	6.5	6.2	6.0	5.7	5.5	5.3
	40	4.9	4.6	4.3	4.2	4.0	3.8	3.6	6.1	5.7	5.4	5.2	5.0	4.8	4.7
	75	4.3	4.0	3.8	3.5	3.3	3.2	3.1	5.3	5.0	4.7	4.5	4.3	4.2	4.1
	90	4.1	3.8	3.5	3.3	3.1	3.0	2.9	5.1	4.8	4.5	4.3	4.2	4.0	3.9
240 x 57	10	6.5	6.1	5.9	5.7	5.5	5.3	5.2	8.1	7.7	7.4	7.2	6.8	6.6	6.4
	20	5.9	5.6	5.4	5.1	5.0	4.8	4.6	7.4	7.0	6.6	6.4	6.2	6.0	5.8
	40	5.3	5.0	4.7	4.5	4.3	4.2	4.1	6.5	6.2	5.8	5.6	5.4	5.2	5.1
	75	4.6	4.3	4.1	3.9	3.7	3.6	3.4	5.7	5.4	5.1	4.9	4.7	4.5	4.4
	90	4.4	4.2	3.9	3.7	3.5	3.3	3.2	5.5	5.2	4.9	4.7	4.5	4.4	4.2
300 x 42	10	7.2	6.8	6.5	6.2	6.0	5.8	5.6	8.9	8.5	8.1	7.8	7.5	7.3	7.0
	20	6.5	6.1	5.8	5.6	5.4	5.2	5.0	8.1	7.6	7.3	7.0	6.7	6.5	6.3
	40	5.7	5.4	5.1	4.9	4.7	4.6	4.4	7.2	6.7	6.4	6.1	5.9	5.7	5.5
	75	5.0	4.7	4.5	4.2	4.1	4.0	3.8	6.3	5.9	5.5	5.3	5.1	4.9	4.8
	90	4.8	4.5	4.3	4.1	3.9	3.7	3.6	6.0	5.6	5.3	5.1	4.9	4.8	4.6
300 x 57	10	7.5	7.2	6.9	6.6	6.4	6.2	6.0	9.3	8.9	8.5	8.3	8.0	7.7	7.5
	20	6.9	6.5	6.2	6.0	5.8	5.6	5.4	8.5	8.1	7.7	7.4	7.2	7.0	6.7
	40	6.1	5.8	5.5	5.3	5.1	5.0	4.8	7.6	7.2	6.8	6.6	6.4	6.2	6.0
	75	5.4	5.1	4.8	4.6	4.4	4.3	4.2	6.7	6.3	6.0	5.7	5.5	5.3	5.2
	90	5.2	4.9	4.6	4.5	4.2	4.1	4.0	6.5	6.1	5.8	5.5	5.3	5.1	5.0

1. Bearing length at end supports to be not less than 30 mm and at intermediate supports for continuous span at least 70mm.

Lintels

In Single or Upper Storey Load Bearing External Walls For N3 wind classification

e-beam Section D X B (mm)	Sheet Roof and Ceiling									
	Roof Load Width 'RLW' (m)									
	1.8	2.4	3.0	3.6	4.2	4.8	5.4	6.0	6.6	7.2
Maximum Span (m)										
150 x 35	2.9	2.7	2.6	2.5	2.4	2.3	2.1	2.0	1.9	1.8
150 x 42	3.1	2.9	2.7	2.6	2.5	2.4	2.4	2.2	2.1	2.1
170 x 35	3.2	3.0	2.8	2.7	2.6	2.5	2.4	2.4	2.3	2.2
170 x 42	3.3	3.1	3.0	2.8	2.7	2.6	2.5	2.5	2.4	2.4
200 x 35	3.6	3.3	3.1	3.0	2.9	2.8	2.7	2.7	2.6	2.5
200 x 42	3.7	3.5	3.3	3.2	3.0	2.9	2.9	2.8	2.7	2.7
200 x 57	4.0	3.8	3.6	3.4	3.3	3.2	3.1	3.0	3.0	2.9
240 x 35	4.0	3.8	3.6	3.4	3.3	3.2	3.1	3.0	2.9	2.9
240 x 42	4.3	4.0	3.8	3.6	3.5	3.4	3.3	3.2	3.1	3.0
240 x 57	4.6	4.3	4.1	3.9	3.8	3.6	3.5	3.5	3.4	3.3
300 x 42	5.0	4.8	4.5	4.2	4.1	4.0	3.9	3.8	3.7	3.6
300 x 57	5.4	5.1	4.8	4.6	4.5	4.3	4.2	4.1	4.0	3.9
300 x 75	5.6	5.3	5.0	4.8	4.7	4.5	4.4	4.2	4.1	4.1
2/300 x 42	5.8	5.5	5.3	5.1	4.9	4.8	4.6	4.5	4.4	4.3
350 x 57	6.1	5.7	5.5	5.3	5.1	5.0	4.8	4.8	4.6	4.5
400 x 42	6.1	5.8	5.5	5.3	5.1	5.0	4.8	4.7	4.6	4.3
400 x 57	6.6	6.2	5.9	5.7	5.5	5.3	5.2	5.1	5.0	4.9
400 x 75	6.9	6.4	6.1	5.9	5.7	5.5	5.4	5.3	5.2	5.1
2/400 x 42	7.1	6.7	6.4	6.1	5.9	5.8	5.6	5.5	5.4	5.3
450 x 57	7.2	6.8	6.4	6.2	6.0	5.8	5.6	5.5	5.4	5.3

e-beam Section D X B (mm)	Tile Roof and Ceiling									
	Roof Load Width 'RLW' (m)									
	1.8	2.4	3.0	3.6	4.2	4.8	5.4	6.0	6.6	7.2
Maximum Span (m)										
150 x 35	2.3	2.0	1.9	1.8	1.7	1.6	1.5	1.5	1.4	1.4
150 x 42	2.4	2.2	2.0	1.9	1.8	1.7	1.7	1.6	1.5	1.5
170 x 35	2.6	2.3	2.2	2.0	1.9	1.8	1.7	1.7	1.6	1.6
170 x 42	2.7	2.5	2.3	2.2	2.0	1.9	1.9	1.8	1.7	1.7
200 x 35	2.9	2.6	2.5	2.4	2.2	2.1	2.0	1.9	1.9	1.8
200 x 42	3.1	2.8	2.6	2.5	2.4	2.3	2.2	2.1	2.0	2.0
200 x 57	3.4	3.1	2.9	2.8	2.6	2.6	2.5	2.4	2.3	2.2
240 x 35	3.4	3.1	2.9	2.8	2.6	2.6	2.5	2.4	2.3	2.2
240 x 42	3.6	3.3	3.1	3.0	2.8	2.7	2.6	2.5	2.5	2.4
240 x 57	3.8	3.6	3.4	3.2	3.1	3.0	2.9	2.8	2.7	2.6
300 x 42	4.1	3.9	3.7	3.5	3.4	3.2	3.2	3.1	3.0	2.9
300 x 57	4.5	4.2	4.0	3.8	3.7	3.6	3.5	3.4	3.3	3.2
300 x 75	4.7	4.3	4.1	3.9	3.9	3.7	3.6	3.5	3.5	3.4
2/300 x 42	4.9	4.6	4.3	4.1	4.0	3.9	3.8	3.7	3.6	3.6
350 x 57	5.1	4.8	4.6	4.3	4.2	4.0	3.9	3.8	3.8	3.7
400 x 42	5.1	4.8	4.6	4.3	4.2	4.0	3.9	3.8	3.8	3.7
400 x 57	5.5	5.2	4.9	4.7	4.6	4.4	4.2	4.1	4.0	4.0
400 x 75	5.8	5.4	5.1	4.9	4.8	4.6	4.4	4.3	4.2	4.1
2/400 x 42	6.0	5.6	5.3	5.1	5.0	4.8	4.7	4.6	4.4	4.3
450 x 57	6.1	5.6	5.3	5.1	5.0	4.8	4.7	4.6	4.4	4.3

1. Bearing length to be not less than 35mm unless indicated otherwise by inclusion of a subscript.
2. Subscript values indicate the required minimum bearing length in millimetres.
3. Multiple sections to be nail laminated in accordance with AS 1684.
4. Lintels to be used in conjunction with top plates, ledgers and head trimmers.
5. It is recommended that a clearance of at least 15mm is allowed over non-loadbearing window or door framing.

Lintels

In Lower Storey Load Bearing External Walls For N3 wind classification

Sheet Roof and Ceiling															
e-beam Section D X B (mm)	Floor Load Width 'FLW' (m)														
	1.8					2.4					3.0				
	Roof Load Width 'RLW' (m)														
	1.8	3.0	4.2	5.4	6.6	1.8	3.0	4.2	5.4	6.6	1.8	3.0	4.2	5.4	6.6
Maximum Span (m)															
150 x 35	1.9	1.8	1.7	1.7	1.6	1.8	1.7	1.6	1.6	1.5	1.7	1.6	1.6	1.5	1.5
150 x 42	2.0	1.9	1.8	1.8	1.7	1.9	1.8	1.8	1.7	1.6	1.8	1.7	1.7	1.6	1.6
170 x 35	2.1	2.0	1.9	1.9	1.8	2.0	1.9	1.8	1.8	1.7	1.9	1.8	1.8	1.7	1.7
170 x 42	2.3	2.2	2.1	2.0	1.9	2.1	2.0	2.0	1.9	1.8	2.0	1.9	1.9	1.8	1.8
200 x 35	2.5	2.3	2.2	2.2	2.1	2.3	2.2	2.1	2.1	2.0	2.2	2.1	2.0	2.0	1.9
200 x 42	2.6	2.5	2.4	2.3	2.2	2.5	2.4	2.3	2.2	2.1	2.4	2.3	2.2	2.1	2.1
200 x 57	2.9	2.8	2.7	2.6	2.5	2.8	2.6	2.5	2.5	2.4	2.6	2.5	2.4	2.4	2.3
2/200 x 35	3.1	3.0	2.9	2.8	2.7	3.0	2.8	2.7	2.6	2.6	2.8	2.7	2.6	2.5	2.5
240 x 35	2.9	2.8	2.7	2.6	2.5	2.8	2.6	2.5	2.5	2.4	2.6	2.5	2.4	2.4	2.3
240 x 42	3.1	3.0	2.9	2.8	2.7	3.0	2.8	2.7	2.6	2.6	2.8	2.7	2.6	2.5	2.5
240 x 57	3.4	3.2	3.1	3.0	3.0	3.2	3.1	3.0	2.9	2.8	3.1	3.0	2.9	2.8	2.7
2/240 x 35	3.5	3.4	3.3	3.2	3.1	3.4	3.3	3.2	3.1	3.0	3.2	3.1	3.1	3.0	2.9
2/240 x 42	3.7	3.6	3.5	3.4	3.3	3.5	3.4	3.3	3.2	3.2	3.4	3.3	3.2	3.2	3.1
300 x 42	3.7	3.5	3.4	3.3	3.2	3.5	3.4	3.3	3.2	3.1	3.4	3.3	3.2	3.1	3.0
300 x 57	4.0	3.8	3.7	3.6	3.5	3.8	3.7	3.6	3.5	3.4	3.6	3.5	3.4	3.4	3.3
300 x 75	4.1	4.0	3.9	3.7	3.6	3.9	3.8	3.7	3.6	3.5	3.8	3.7	3.6	3.5	3.4
2/300 x 42	4.3	4.2	4.0	3.9	3.8	4.1	4.0	3.9	3.8	3.7	4.0	3.9	3.8	3.7	3.6
350 x 57	4.5	4.4	4.2	4.1	4.0	4.3	4.2	4.1	4.0	3.9	4.2	4.0	3.9	3.9	3.8
400 x 42	4.5	4.4	4.2	4.1	4.0	4.3	4.2	4.1	4.0	3.9	4.1	4.0	3.9	3.8	3.8
400 x 57	4.9	4.7	4.6	4.4	4.3	4.7	4.5	4.4	4.3	4.2	4.5	4.4	4.3	4.2	4.1
400 x 75	5.1	4.9	4.8	4.6	4.5	4.9	4.7	4.6	4.5	4.4	4.7	4.6	4.4	4.4	4.3
450 x 57	5.3	5.1	5.0	4.8	4.7	5.1	4.9	4.8	4.7	4.6	4.9	4.8	4.7	4.6	4.5

1. Bearing length to be not less than 35mm unless indicated otherwise by inclusion of a subscript.
2. Subscript values indicate the required minimum bearing length in millimetres.
3. Multiple sections to be nail laminated in accordance with AS 1684.
4. Lintels to be used in conjunction with top plates, ledgers and head trimmers.
5. It is recommended that a clearance of at least 15mm is allowed over non-loadbearing window or door framing.

Lintels

In Lower Storey Load Bearing External Walls For N3 wind classification

Tile Roof and Ceiling															
e-beam Section D X B (mm)	Floor Load Width 'FLW' (m)														
	1.8					2.4					3.0				
	Roof Load Width 'RLW' (m)														
	1.8	3.0	4.2	5.4	6.6	1.8	3.0	4.2	5.4	6.6	1.8	3.0	4.2	5.4	6.6
Maximum Span (m)															
150 x 35	1.7	1.6	1.5	1.4	1.3	1.7	1.5	1.4	1.4	1.3	1.6	1.5	1.4	1.3	1.3
150 x 42	1.9	1.7	1.6	1.5	1.4	1.8	1.6	1.5	1.5	1.4	1.7	1.6	1.5	1.4	1.4
170 x 35	1.9	1.8	1.7	1.6	1.5	1.8	1.7	1.6	1.5	1.5	1.8	1.7	1.6	1.5	1.4
170 x 42	2.1	1.9	1.8	1.7	1.6	2.0	1.8	1.7	1.6	1.6	1.9	1.8	1.7	1.6	1.5
200 x 35	2.3	2.1	1.9	1.8	1.7	2.1	2.0	1.9	1.8	1.7	2.1	1.9	1.8	1.7	1.7
200 x 42	2.4	2.2	2.1	2	1.9	2.3	2.1	2.0	1.9	1.8	2.2	2.1	2.0	1.9	1.8
200 x 57	2.7	2.5	2.3	2.2	2.1	2.6	2.4	2.2	2.1	2.0	2.4	2.3	2.2	2.1	2.0
2/200 x 35	2.9	2.7	2.5	2.4	2.2	2.8	2.6	2.4	2.3	2.2	2.6	2.5	2.3	2.2	2.1
240 x 35	2.7	2.5	2.3	2.2	2.1	2.6	2.4	2.2	2.1	2.0	2.4	2.3	2.2	2.1	2.0
240 x 42	2.9	2.6	2.5	2.3	2.2	2.7	2.5	2.4	2.3	2.2	2.6	2.5	2.3	2.2	2.1
240 x 57	3.1	2.9	2.8	2.6	2.5	3.0	2.8	2.7	2.5	2.4	2.9	2.7	2.6	2.5	2.4
2/240 x 35	3.3	3.1	2.9	2.8	2.6	3.2	3.0	2.8	2.7	2.6	3.1	2.9	2.8	2.6	2.5
2/240 x 42	3.5	3.3	3.1	3	2.8	3.3	3.2	3.0	2.9	2.8	3.2	3.1	3.0	2.8	2.7
300 x 42	3.4	3.2	3.1	2.9	2.8	3.3	3.1	3.0	2.8	2.7	3.2	3.0	2.9	2.8	2.6
300 x 57	3.7	3.5	3.3	3.2	3.1	3.6	3.4	3.2	3.1	3.0	3.5	3.3	3.2	3.1	3.0
300 x 75	3.9	3.6	3.5	3.3	3.2	3.7	3.5	3.4	3.3	3.1	3.6	3.4	3.3	3.2	3.1
2/300 x 42	4.1	3.8	3.6	3.5	3.4	3.9	3.7	3.6	3.4	3.3	3.8	3.6	3.5	3.4	3.3
350 x 57	4.2	4	3.8	3.6	3.5	4.1	3.9	3.7	3.6	3.5	4.0	3.8	3.6	3.5	3.4
400 x 42	4.2	4	3.8	3.6	3.5	4.1	3.9	3.7	3.6	3.4	3.9	3.8	3.6	3.5	3.4
400 x 57	4.6	4.3	4.1	3.9	3.8	4.4	4.2	4.0	3.9	3.7	4.3	4.1	3.9	3.8	3.7
400 x 75	4.8	4.5	4.3	4.1	4	4.6	4.4	4.2	4.0	3.9	4.5	4.3	4.1	3.9	3.8
450 x 57	5	4.7	4.5	4.3	4.1	4.8	4.6	4.4	4.2	4.1	4.7	4.4	4.3	4.1	4.0

1. Bearing length to be not less than 35mm unless indicated otherwise by inclusion of a subscript.
2. Subscript values indicate the required minimum bearing length in millimetres.
3. Multiple sections to be nail laminated in accordance with AS 1684.
4. Lintels to be used in conjunction with top plates, ledgers and head trimmers.
5. It is recommended that a clearance of at least 15mm is allowed over non-loadbearing window or door framing.

Lintels

Supporting Truncated Girder Truss For N3 wind classification

e-beam Section D X B (mm)	2400 Setback					
	Sheet Roof and Ceiling			Tile Roof and Ceiling		
	Truss Span (m)			Truss Span (m)		
	6.0	7.5	9.0	6.0	7.5	9.0
Maximum Span (m)						
130 x 35	1.8	1.7	1.6	1.3	1.3	1.2
130 x 42	2.0	1.8	1.7	1.5	1.3	1.3
150 x 35	2.2	2.0	1.8	1.6	1.4	1.3
150 x 42	2.4	2.2	2.0	1.6	1.5	1.4
170 x 35	2.5	2.3	2.2	1.7	1.6	1.5
170 x 42	2.6	2.5	2.4	1.9	1.8	1.6
200 x 42	3.0	2.9	2.8	2.3	2.1	2.0
200 x 57	3.3	3.2	3.0	2.6	2.4	2.3
2/200 x 42	3.7	3.5	3.4	3.0	2.8	2.7
240 x 42	3.5	3.4	3.2	2.8	2.6	2.5
240 x 57	3.8	3.7	3.5	3.1	2.9	2.8
2/240 x 42	4.3	4.0	3.9	3.4	3.3	3.2
300 x 42	4.2	4.0	3.8	3.4	3.2	3.1
300 x 57	4.6	4.4	4.2	3.7	3.6	3.4
300 x 75	4.8	4.6	4.4	3.9	3.7	3.6
2/300 x 42	5.0	4.8	4.7	4.1	3.9	3.8
350 x 57	5.3	5.1	4.9	4.3	4.1	3.9
400 x 57	5.7	5.5	5.3	4.7	4.5	4.3
400 x 75	5.9	5.7	5.5	4.9	4.7	4.5
450 x 57	6.2	6.0	5.8	5.1	4.9	4.7

e-beam Section D X B (mm)	3500 Setback					
	Sheet Roof and Ceiling			Tile Roof and Ceiling		
	Truss Span (m)			Truss Span (m)		
	9.0	10.5	12.0	9.0	10.5	12.0
Maximum Span (m)						
130 x 35	1.4	1.2	1.0	1.1	0.9	0.8
130 x 42	1.5	1.4	1.3	1.2	1.1	1.0
150 x 35	1.7	1.5	1.3	1.2	1.2	1.0
150 x 42	1.9	1.7	1.6	1.3	1.2	1.2
170 x 35	2.0	1.8	1.6	1.4	1.3	1.1
170 x 42	2.2	2.0	1.9	1.5	1.4	1.3
200 x 42	2.6	2.5	2.4	1.8	1.7	1.6
200 x 57	2.9	2.7	2.6	2.1	2.0	1.8
2/200 x 42	3.3	3.1	3.0	2.5	2.4	2.2
240 x 42	3.1	3.0	2.8	2.3	2.1	2.0
240 x 57	3.4	3.2	3.1	2.6	2.5	2.4
2/240 x 42	3.8	3.6	3.5	3.0	2.9	2.7
300 x 42	3.7	3.6	3.4	3.0	2.8	2.7
300 x 57	4.1	3.9	3.8	3.3	3.1	3.0
300 x 75	4.2	4.1	4.0	3.4	3.3	3.2
2/300 x 42	4.5	4.3	4.2	3.6	3.5	3.3
350 x 57	4.7	4.5	4.4	3.8	3.7	3.5
400 x 57	5.1	4.9	4.8	4.1	4.0	3.9
400 x 75	5.3	5.2	5.0	4.3	4.2	4.0
450 x 57	5.6	5.4	5.3	4.6	4.4	4.3

1. Bearing length to be not less than 35mm unless indicated otherwise by inclusion of a subscript.
2. Subscript values indicate the required minimum bearing length in millimetres.
3. Multiple sections to be nail laminated in accordance with AS 1684.
4. Lintels to be used in conjunction with top plates, ledgers and head trimmers.
5. It is recommended that a clearance of at least 15mm is allowed over non-loadbearing window or door framing.
6. Maximum rafter or truss spacing - 600 mm for tile roofs, 1200 mm for sheet roofs.

Lintels Supporting Strutting Beams

Strutting Beam Supporting Underpurlins and Hanging Beams For N3 wind classification

e-beam Section D X B (mm)	Maximum Hanging Beam and/or Underpurlin Spans (m)	Sheet Roof and Ceiling					Tile Roof and Ceiling				
		Strutting Beam Span (m)									
		3.6	4.2	4.8	5.4	6.0	3.6	4.2	4.8	5.4	6.0
		Maximum Span (m)									
130 x 35	2.4	2.1	2.0	1.9	1.8	1.7	1.5	1.4	1.4	1.3	1.3
	4.2	1.8	1.7	1.6	1.5	1.4	1.3	1.2	1.2	1.1	1.1
130 x 42	2.4	2.3	2.2	2.1	1.9	1.9	1.6	1.5	1.4	1.4	1.3
	4.2	2.0	1.9	1.8	1.7	1.6	1.4	1.3	1.3	1.2	1.2
150 x 42	2.4	2.6	2.5	2.4	2.3	2.2	1.8	1.7	1.7	1.6	1.5
	4.2	2.4	2.2	2.1	2.0	1.9	1.6	1.5	1.5	1.4	1.3
150 x 57	2.4	2.8	2.8	2.6	2.6	2.5	2.1	2.0	1.9	1.8	1.7
	4.2	2.6	2.5	2.4	2.3	2.2	1.9	1.7	1.6	1.6	1.5
170 x 42	2.4	2.9	2.8	2.7	2.6	2.5	2.1	2.0	1.9	1.8	1.7
	4.2	2.7	2.5	2.5	2.4	2.2	1.9	1.7	1.7	1.6	1.5
170 x 57	2.4	3.1	3.0	3.0	2.9	2.8	2.4	2.3	2.2	2.0	2.0
	4.2	3.0	2.8	2.7	2.6	2.5	2.2	2.0	1.9	1.8	1.8
200 x 35	2.4	3.1	3.0	2.9	2.8	2.7	2.4	2.2	2.1	2.0	1.9
	4.2	2.9	2.8	2.7	2.6	2.5	2.1	2.0	1.9	1.8	1.7
200 x 42	2.4	3.3	3.2	3.1	3.0	2.9	2.5	2.4	2.3	2.2	2.1
	4.2	3.1	3.0	2.9	2.8	2.7	2.3	2.1	2.0	1.9	1.8
200 x 57	2.4	3.5	3.5	3.4	3.3	3.2	2.8	2.7	2.6	2.5	2.4
	4.2	3.3	3.3	3.2	3.1	3.0	2.6	2.5	2.3	2.2	2.1
240 x 42	2.4	3.8	3.7	3.6	3.4	3.4	3.0	2.9	2.8	2.7	2.6
	4.2	3.6	3.5	3.4	3.2	3.2	2.8	2.6	2.5	2.4	2.4
240 x 57	2.4	4.1	4.0	3.9	3.8	3.7	3.3	3.2	3.1	3.0	2.9
	4.2	3.9	3.8	3.7	3.5	3.5	3.1	3.0	2.9	2.7	2.7
2/240 x 42	2.4	4.6	4.4	4.3	4.2	4.1	3.7	3.5	3.5	3.4	3.2
	4.2	4.4	4.2	4.1	4.0	3.9	3.5	3.3	3.3	3.2	3.0
300 x 57	2.4	4.9	4.8	4.7	4.6	4.4	3.9	3.8	3.7	3.6	3.6
	4.2	4.7	4.6	4.4	4.3	4.2	3.7	3.6	3.5	3.4	3.3
300 x 75	2.4	5.1	5.0	4.9	4.8	4.7	4.1	4.0	3.9	3.8	3.7
	4.2	4.9	4.8	4.7	4.5	4.4	3.9	3.8	3.7	3.6	3.5
2/300 x 42	2.4	5.4	5.2	5.1	5.0	4.9	4.3	4.2	4.1	4.0	3.9
	4.2	5.2	5.0	4.9	4.8	4.7	4.1	4.0	3.9	3.8	3.7
350 x 57	2.4	5.6	5.4	5.3	5.2	5.1	4.5	4.4	4.3	4.1	4.1
	4.2	5.4	5.2	5.1	5.0	4.9	4.3	4.2	4.1	3.9	3.9
400 x 57	2.4	6.1	5.9	5.8	5.6	5.5	4.9	4.8	4.7	4.5	4.4
	4.2	5.9	5.7	5.6	5.4	5.3	4.7	4.6	4.4	4.3	4.2
400 x 75	2.4	6.3	6.2	6.0	5.9	5.8	5.2	5.0	4.9	4.8	4.6
	4.2	6.1	5.9	5.8	5.6	5.5	5.0	4.8	4.6	4.5	4.4
450 x 57	2.4	6.7	6.5	6.3	6.2	6.1	5.4	5.3	5.1	5.0	4.9
	4.2	6.5	6.2	6.1	5.9	5.8	5.2	5.1	4.9	4.8	4.7

1. Bearing length to be not less than 35mm unless indicated otherwise by inclusion of a subscript.
2. Subscript values indicate the required minimum bearing length in millimetres.
3. Multiple sections to be nail laminated in accordance with AS 1684.
4. Lintels to be used in conjunction with top plates, ledgers and head trimmers.
5. It is recommended that a clearance of at least 15mm is allowed over non-loadbearing window or door framing.
6. Maximum rafter spacing - 600 mm for tile roofs, 1200 mm for sheet roofs.

Floor Joists

Supporting Floor Loads only

e-beam Section D X B (mm)	Floor Joist Spacing (mm)									
	300		400		450		480		600	
	Maximum single span and cantilever (m)									
	Span	Cant.	Span	Cant.	Span	Cant.	Span	Cant.	Span	Cant.
95 x 35	2.1	0.5	1.8	0.5	1.8	0.4	1.7	0.4	1.7	0.4
95 x 42	2.3	0.6	2.0	0.5	1.9	0.5	1.9	0.5	1.8	0.4
130 x 35	3.3	0.8	2.6	0.8	2.5	0.7	2.4	0.7	2.3	0.6
130 x 42	3.6	0.9	2.8	0.8	2.7	0.8	2.7	0.8	2.5	0.7
150 x 35	3.8	0.9	3.0	0.9	3.0	0.8	2.9	0.8	2.7	0.8
150 x 42	4.0	1.0	3.3	0.9	3.2	0.9	3.1	0.9	3.0	0.8
170 x 35	4.2	1.1	3.5	1.0	3.4	1.0	3.3	0.9	3.1	0.9
170 x 42	4.4	1.2	3.8	1.1	3.8	1.0	3.6	1.0	3.4	0.9
200 x 35	4.7	1.3	4.3	1.1	4.2	1.1	4.0	1.1	3.8	1.0
200 x 42	5.0	1.4	4.6	1.2	4.4	1.2	4.4	1.2	4.1	1.1
240 x 35	5.4	1.5	5.0	1.4	4.8	1.3	4.9	1.3	4.5	1.2
240 x 42	5.7	1.6	5.3	1.5	5.1	1.4	5.1	1.4	4.8	1.3
300 x 42	6.7	1.9	6.3	1.8	6.0	1.7	6.1	1.7	5.7	1.6
350 x 42	7.7	2.2	7.2	2.0	7.0	2.0	6.9	1.9	6.5	1.8
400 x 42	8.3	2.4	7.8	2.2	7.5	2.1	7.4	2.1	7.0	2.0
Maximum continuous span and cantilever (m)										
95 x 35	2.8	0.5	2.1	0.5	2.1	0.4	2.0	0.4	1.9	0.4
95 x 42	3.0	0.5	2.3	0.5	2.3	0.5	2.2	0.5	2.1	0.4
130 x 35	3.9	0.8	3.1	0.7	3.0	0.7	2.9	0.7	2.7	0.6
130 x 42	4.2	0.9	3.4	0.8	3.3	0.8	3.2	0.7	3.0	0.7
150 x 35	4.4	0.9	3.8	0.9	3.6	0.8	3.4	0.8	3.2	0.7
150 x 42	4.6	1.0	4.2	0.9	4.0	0.9	3.8	0.9	3.5	0.8
170 x 35	4.8	1.1	4.5	1.0	4.3	0.9	4.0	0.9	3.7	0.8
170 x 42	5.1	1.1	4.8	1.0	4.5	1.0	4.4	1.0	4.0	0.9
200 x 35	5.5	1.3	5.1	1.1	4.9	1.1	4.8	1.1	4.5	1.0
200 x 42	5.8	1.4	5.4	1.2	5.2	1.2	5.1	1.2	4.8	1.1
240 x 35	6.3	1.5	5.8	1.4	5.7	1.3	5.6	1.3	5.3	1.2
240 x 42	6.6	1.6	6.2	1.5	6.0	1.4	5.9	1.4	5.6	1.3
300 x 42	7.8	1.9	7.3	1.8	7.1	1.7	6.9	1.7	6.6	1.6

1. Joists with D/B > 4 should be blocked at supports as per AS 1684.
2. Cantilever spans should not exceed one half of the installed backspan.

Floor Joists

For Tiled Floors or Floors Supporting Heavy Furniture

e-beam Section D X B (mm)	Floor joist spacing (mm)					Floor joist spacing (mm)				
	300	400	450	480	600	300	400	450	480	600
	Maximum single span (m)					Maximum continuous span (m)				
95 x 35	2.1	1.8	1.7	1.8	1.7	2.6	2.1	2.0	2.1	1.9
95 x 42	2.2	2.0	1.9	1.9	1.8	2.8	2.3	2.2	2.3	2.1
130 x 35	2.9	2.6	2.4	2.5	2.3	3.6	3.1	2.9	3.0	2.7
130 x 42	3.1	2.8	2.7	2.6	2.5	3.8	3.4	3.2	3.3	3.0
150 x 35	3.3	3.0	2.9	2.8	2.6	4.1	3.7	3.4	3.5	3.2
150 x 42	3.5	3.2	3.1	3.0	2.8	4.4	4.0	3.8	3.8	3.5
170 x 35	3.7	3.4	3.3	3.2	3.0	4.6	4.2	4.0	4.0	3.7
170 x 42	4.0	3.6	3.5	3.4	3.2	4.8	4.5	4.4	4.3	4.0
200 x 35	4.3	4.0	3.8	3.8	3.5	5.2	4.8	4.7	4.6	4.4
200 x 42	4.6	4.3	4.1	4.0	3.8	5.5	5.1	5.0	4.9	4.6
240 x 35	5.0	4.7	4.6	4.5	4.2	5.9	5.5	5.4	5.3	5.0
240 x 42	5.2	4.9	4.8	4.7	4.5	6.2	5.8	5.7	5.6	5.3
300 x 42	6.1	5.8	5.6	5.6	5.3	7.3	6.9	6.7	6.6	6.3
350 x 42	7.0	6.6	6.4	6.3	6.0	8.3	7.8	7.6	7.5	7.1
400 x 42	7.5	7.1	6.9	6.8	6.5	9.0	8.4	8.2	8.1	7.7

1. Joists with $D/B > 4$ should be blocked at supports as per AS 1684.
2. Tables apply where the imposed load from floor coverings (tiles & mortar) or heavy furniture is between 50 and 100 kilogram per square metre.

Floor Joists

Supporting Parallel Load Bearing Walls Over Openings

Tile Roof And Ceiling																		
e-beam Section D X B (mm)	Single Span										Continuous Span							
	Roof Load Width 'RLW' (m)																	
	1.8	2.4	3.0	3.6	4.2	4.8	5.4	6.0	6.6	1.8	2.4	3.0	3.6	4.2	4.8	5.4	6.0	6.6
	Maximum Span (m)																	
2/95 x 35	1.5	1.4	1.4	1.3	1.2	1.2	1.2	1.1	1.1	2.1	1.9	1.8	1.7	1.7	1.6	1.6	1.5	1.5
2/95 x 42	1.7	1.6	1.5	1.4	1.3	1.3	1.2	1.2	1.2	2.2	2.1	2.0	1.9	1.8	1.7	1.7	1.6	1.6
2/130 x 35	2.1	2.0	1.9	1.8	1.7	1.6	1.6	1.5	1.5	2.8	2.6	2.5	2.4	2.3	2.2	2.1	2.1	2.0
2/130 x 42	2.3	2.1	2.0	1.9	1.8	1.8	1.7	1.7	1.6	3.0	2.8	2.7	2.6	2.5	2.4	2.3	2.2	2.2
2/150 x 35	2.4	2.3	2.2	2.0	2.0	1.9	1.8	1.8	1.7	3.3	3.1	2.9	2.7	2.6	2.5	2.5	2.4	2.3
2/150 x 42	2.6	2.4	2.3	2.2	2.1	2.0	2.0	1.9	1.9	3.5	3.3	3.1	3.0	2.8	2.7	2.6	2.6	2.5
2/170 x 35	2.8	2.6	2.4	2.3	2.2	2.1	2.1	2.0	2.0	3.7	3.5	3.3	3.1	3.0	2.9	2.8	2.7	2.6
2/170 x 42	3.0	2.8	2.6	2.5	2.4	2.3	2.2	2.2	2.1	4.0	3.7	3.5	3.3	3.2	3.1	3.0	2.9	2.8
2/200 x 35	3.2	3.0	2.9	2.7	2.6	2.5	2.4	2.4	2.3	4.3	4.1	3.8	3.7	3.5	3.4	3.3	3.2	3.1
2/200 x 42	3.5	3.3	3.1	2.9	2.8	2.7	2.6	2.5	2.5	4.6	4.4	4.1	3.9	3.8	3.6	3.5	3.4	3.3
2/240 x 42	4.2	3.9	3.7	3.5	3.4	3.2	3.1	3.0	3.0	5.3	5.0	4.8	4.7	4.5	4.3	4.2	4.1	4.0
2/300 x 42	5.0	4.8	4.6	4.4	4.2	4.0	3.9	3.8	3.7	6.2	5.9	5.7	5.5	5.3	5.2	5.0	4.9	4.8
2/350 x 42	5.7	5.4	5.2	5.0	4.9	4.8	4.6	4.5	4.4	7.1	6.8	6.5	6.3	6.1	5.9	5.7	5.5	5.3
2/400 x 42	6.2	5.9	5.6	5.4	5.3	5.1	5.0	4.9	4.8	7.7	7.3	6.9	6.7	6.4	6.1	5.9	5.7	5.6

Sheet Roof And Ceiling																		
e-beam Section D X B (mm)	Single Span										Continuous Span							
	Roof Load Width 'RLW' (m)																	
	1.8	2.4	3.0	3.6	4.2	4.8	5.4	6.0	6.6	1.8	2.4	3.0	3.6	4.2	4.8	5.4	6.0	6.6
	Maximum Span (m)																	
2/95 x 35	1.8	1.7	1.7	1.6	1.5	1.5	1.4	1.4	1.4	2.4	2.3	2.2	2.1	2.1	2.0	1.9	1.9	1.8
2/95 x 42	2.0	1.9	1.8	1.7	1.7	1.6	1.6	1.5	1.5	2.6	2.5	2.4	2.3	2.2	2.1	2.1	2.0	2.0
2/130 x 35	2.5	2.4	2.3	2.2	2.1	2.0	2.0	1.9	1.9	3.3	3.2	3.0	2.9	2.8	2.7	2.6	2.6	2.5
2/130 x 42	2.7	2.5	2.4	2.3	2.3	2.2	2.1	2.1	2.0	3.6	3.4	3.3	3.1	3.0	2.9	2.8	2.8	2.7
2/150 x 35	2.9	2.7	2.6	2.5	2.4	2.3	2.3	2.2	2.2	3.8	3.6	3.5	3.4	3.2	3.1	3.1	3.0	2.9
2/150 x 42	3.1	2.9	2.8	2.7	2.6	2.5	2.4	2.4	2.3	4.1	3.9	3.7	3.6	3.5	3.4	3.3	3.2	3.1
2/170 x 35	3.2	3.1	2.9	2.8	2.7	2.7	2.6	2.5	2.4	4.3	4.1	3.9	3.8	3.7	3.6	3.5	3.4	3.3
2/170 x 42	3.5	3.3	3.2	3.0	2.9	2.8	2.8	2.7	2.6	4.6	4.4	4.2	4.1	3.9	3.8	3.7	3.6	3.5
2/200 x 35	3.8	3.6	3.5	3.3	3.2	3.1	3.0	2.9	2.9	4.9	4.8	4.6	4.5	4.3	4.2	4.1	4.0	3.9
2/200 x 42	4.1	3.9	3.7	3.6	3.4	3.3	3.3	3.2	3.1	5.2	5.0	4.8	4.7	4.6	4.5	4.4	4.2	4.1
2/240 x 42	4.8	4.6	4.4	4.3	4.1	4.0	3.9	3.8	3.7	5.9	5.7	5.5	5.4	5.3	5.1	5.0	4.9	4.8
2/300 x 42	5.6	5.4	5.2	5.1	5.0	4.9	4.8	4.7	4.6	7.0	6.7	6.5	6.3	6.2	6.1	5.9	5.8	5.7
2/350 x 42	6.4	6.2	6.0	5.8	5.7	5.6	5.4	5.3	5.2	8.0	7.7	7.4	7.2	7.1	6.9	6.8	6.6	6.5
2/400 x 42	6.9	6.6	6.5	6.3	6.1	6.0	5.9	5.8	5.7	8.6	8.3	8.0	7.8	7.6	7.5	7.3	7.2	7.1

1. Bearing length to be not less than 30mm at end supports and not less than 70mm at intermediate supports for continuous span joists unless noted otherwise by a subscript.
2. For single span joists subscript value indicates the required bearing length (in millimetre) for end supports.
3. For continuous span joists, subscript value indicates the required length (in millimetre) at intermediate supports; the bearing length at end supports should be at least one third the bearing length required at the intermediate support but in any case, is not to be less than 30mm.

Bearers

Supporting Floor Loads only

e-beam Section D X B (mm)	Floor Load Width 'FLW' (m)											
	1.2	1.5	1.8	2.1	2.4	2.7	3.0	3.6	4.2	4.8	5.4	6.0
	Maximum single span (m)											
95 x 57	1.9	1.7	1.6	1.6	1.5	1.4	1.4	1.3	1.2	1.2	1.1	1.1
130 x 57	2.6	2.4	2.2	2.1	2.0	1.9	1.9	1.8	1.7	1.6	1.5	1.5
150 x 57	2.9	2.7	2.6	2.4	2.3	2.2	2.2	2.0	1.9	1.8	1.7	1.7
150 x 75	3.1	2.9	2.7	2.6	2.5	2.4	2.3	2.1	2.0	1.9	1.8	1.8
170 x 57	3.3	3.1	2.9	2.8	2.6	2.5	2.4	2.3	2.2	2.1	2.0	1.9
200 x 57	3.8	3.6	3.4	3.2	3.1	3.0	2.9	2.7	2.5	2.4	2.3	2.2
240 x 57	4.4	4.1	4.0	3.8	3.7	3.6	3.4	3.2	3.1	2.9	2.8	2.7
300 x 57	5.1	4.9	4.7	4.5	4.3	4.2	4.1	3.9	3.8	3.6	3.5	3.3
300 x 75	5.3	5.1	4.9	4.7	4.5	4.4	4.3	4.1	3.9	3.8	3.7	3.5
350 x 57	5.9	5.6	5.3	5.1	5.0	4.8	4.7	4.5	4.3	4.1	4.0	3.9
400 x 57	6.3	6.0	5.8	5.5	5.4	5.2	5.1	4.8	4.6	4.5	4.3	4.2
400 x 75	6.6	6.2	6.0	5.8	5.6	5.4	5.3	5.0	4.8	4.7	4.5	4.4
450 x 57	6.9	6.5	6.3	6.0	5.8	5.7	5.5	5.3	5.1	4.9	4.7	4.6
Maximum continuous span												
95 x 57	2.3	2.2	2.0	1.9	1.9	1.8	1.7	1.6	1.4	1.4	1.3	1.2
130 x 57	3.2	3.0	2.8	2.7	2.5	2.4	2.4	2.2	2.0	1.9	1.7	1.7
150 x 57	3.6	3.4	3.2	3.1	2.9	2.8	2.7	2.6	2.3	2.1	2.0	2.0
150 x 75	3.7	3.5	3.4	3.2	3.1	3.0	2.9	2.7	2.6	2.4	2.2	2.1
170 x 57	3.9	3.7	3.5	3.4	3.3	3.2	3.1	2.9	2.7	2.4	2.3	2.1
200 x 57	4.4	4.2	4.0	3.9	3.7	3.6	3.5	3.4	3.1	2.9	2.7	2.6
240 x 57	5.1	4.8	4.6	4.4	4.3	4.2	4.0	3.9	3.7	3.5	3.3	3.1
300 x 57	6.0	5.7	5.4	5.2	5.1	4.9	4.8	4.6	4.4	4.3	4.1	3.9
300 x 75	6.3	5.9	5.7	5.5	5.3	5.1	5.0	4.8	4.6	4.4	4.3	4.2
350 x 57	6.9	6.5	6.2	6.0	5.8	5.6	5.5	5.2	5.0	4.9	4.7	4.6
400 x 57	7.5	7.1	6.7	6.5	6.3	6.1	5.9	5.7	5.5	5.3	5.1	4.9
400 x 75	7.8	7.4	7.0	6.8	6.6	6.4	6.2	5.9	5.7	5.5	5.3	5.2
450 x 57	8.1	7.7	7.4	7.1	6.9	6.7	6.5	6.2	6.0	5.8	5.6	5.3

1. Sections with depth 200mm or greater must be restrained against rollover at supports.
2. Bearing length to be not less than 45mm at end supports or 90mm at intermediate supports for continuous span except where otherwise indicated by a subscript to the maximum span.
3. For single span bearers the subscript value indicates the required bearing length at end supports.
4. For continuous span, the subscript value indicates the minimum bearing length required at intermediate supports; the bearing length at end supports must be at least one third of the bearing length indicated for the intermediate support but not less than 45mm.

Bearers

Supporting Single or Upper Storey Load Bearing Walls For N3 wind classification

e-beam Section D X B (mm)	Sheet Roof And Ceiling														
	Floor Load Width 'FLW' (m)														
	1.2					2.1					3.0				
	Roof Load Width 'RLW' (m)														
	1.8	3.0	4.2	5.4	6.6	1.8	3.0	4.2	5.4	6.6	1.8	3.0	4.2	5.4	6.6
Maximum single span (m)															
95 x 57	1.5	1.4	1.3	1.3	1.2	1.3	1.3	1.2	1.2	1.1	1.2	1.2	1.1	1.1	1.1
130 x 57	2.0	1.9	1.8	1.7	1.7	1.8	1.7	1.7	1.6	1.6	1.7	1.6	1.6	1.5	1.5
150 x 57	2.4	2.2	2.1	2.0	1.9	2.1	2.0	1.9	1.9	1.8	1.9	1.9	1.8	1.8	1.7
170 x 57	2.7	2.5	2.4	2.3	2.2	2.4	2.3	2.2	2.1	2.0	2.2	2.1	2.0	2.0	1.9
200 x 57	3.1	2.9	2.8	2.7	2.6	2.8	2.7	2.6	2.5	2.4	2.6	2.5	2.4	2.3	2.3
240 x 57	3.7	3.5	3.3	3.2	3.1	3.4	3.2	3.1	3.0	2.9	3.1	3.0	2.9	2.8	2.7
300 x 57	4.4	4.2	4.0	3.9	3.8	4.0	3.9	3.8	3.7	3.6	3.8	3.7	3.6	3.5	3.4
300 x 75	4.6	4.4	4.2	4.0	3.9	4.2	4.1	3.9	3.8	3.8	4.0	3.8	3.8	3.7	3.6
350 x 57	5.0	4.8	4.6	4.4	4.3	4.6	4.5	4.3	4.2	4.1	4.3	4.2	4.1	4.0	4.0
400 x 57	5.4	5.2	5.0	4.8	4.7	5.0	4.8	4.7	4.6	4.5	4.7	4.6	4.5	4.4	4.3
400 x 75	5.6	5.4	5.2	5.0	4.9	5.2	5.0	4.9	4.8	4.6	4.9	4.8	4.7	4.5	4.5
450 x 57	5.9	5.6	5.4	5.2	5.1	5.4	5.3	5.1	5.0	4.9	5.1	5.0	4.9	4.8	4.7
Maximum continuous span (m)															
95 x 57	2.0	1.9	1.8	1.7	1.6	1.8	1.7	1.6	1.6	1.5	1.6	1.6	1.5	1.5	1.5
130 x 57	2.7	2.6	2.4	2.3	2.2	2.5	2.3	2.2	2.2	2.1	2.3	2.2	2.1	2.0	2.0
150 x 57	3.2	3.0	2.8	2.7	2.6	2.8	2.7	2.6	2.5	2.4	2.6	2.5	2.4	2.4	2.3
150 x 75	3.3	3.1	3.0	2.8	2.7	3.0	2.9	2.7	2.6	2.6	2.8	2.7	2.6	2.5	2.4
170 x 57	3.6	3.4	3.2	3.0	2.9	3.2	3.1	2.9	2.8	2.7	2.9	2.8	2.7	2.7	2.6
200 x 57	4.0	3.9	3.7	3.6	3.4	3.7	3.6	3.4	3.3	3.2	3.5	3.3	3.2	3.1	3.0
240 x 57	4.6	4.4	4.2	4.1	4.0	4.3	4.1	4.0	3.9	3.8	4.0	3.9	3.8	3.7	3.6
300 x 57	5.4	5.2	5.0	4.8	4.7	5.0	4.9	4.7	4.6	4.5	4.7	4.6	4.5	4.4	4.3
300 x 75	5.7	5.4	5.2	5.0	4.9	5.2	5.1	4.9	4.8	4.7	4.9	4.8	4.7	4.6	4.5
350 x 57	6.2	5.9	5.7	5.5	5.4	5.8	5.6	5.4	5.3	5.1	5.4	5.3	5.1	5.0	4.9
400 x 57	6.7	6.4	6.2	6.0	5.8	6.2	6.0	5.8	5.7	5.5	5.8	5.7	5.6	5.4	5.3
400 x 75	7.0	6.7	6.4	6.2	6.1	6.5	6.3	6.1	5.9	5.8	6.1	5.9	5.8	5.7	5.6
450 x 57	7.3	7.0	6.7	6.5	6.3	6.8	6.6	6.4	6.2	6.1	6.4	6.2	6.1	5.9	5.8

1. Sections with depth 200mm or greater must be restrained against rollover at supports.
2. Bearing length to be not less than 45mm at end supports or 90mm at intermediate supports for continuous span except where otherwise indicated by a subscript to the maximum span.
3. For single span bearers the subscript value indicates the required bearing length at end supports.
4. For continuous span, the subscript value indicates the minimum bearing length required at intermediate supports; the bearing length at end supports must be at least one third of the bearing length indicated for the intermediate support but not less than 45mm.

Bearers

Supporting Single or Upper Storey Load Bearing Walls For N3 wind classification

Tile Roof And Ceiling															
e-beam Section D X B (mm)	Floor Load Width 'FLW' (m)														
	1.2					2.1					3.0				
	Roof Load Width 'RLW' (m)														
	1.8	3.0	4.2	5.4	6.6	1.8	3.0	4.2	5.4	6.6	1.8	3.0	4.2	5.4	6.6
Maximum single span (m)															
95 x 57	1.3	1.2	1.1	1.1	1.0	1.2	1.1	1.1	1.0	1.0	1.2	1.1	1.0	1.0	0.9
130 x 57	1.8	1.7	1.5	1.4	1.4	1.7	1.6	1.5	1.4	1.3	1.6	1.5	1.4	1.3	1.3
150 x 57	2.1	1.9	1.8	1.7	1.6	1.9	1.8	1.7	1.6	1.5	1.8	1.7	1.6	1.5	1.5
170 x 57	2.4	2.2	2.0	1.9	1.8	2.2	2.0	1.9	1.8	1.7	2.1	1.9	1.8	1.7	1.7
200 x 57	2.8	2.5	2.4	2.2	2.1	2.6	2.4	2.2	2.1	2.0	2.4	2.3	2.1	2.0	2.0
240 x 57	3.4	3.1	2.8	2.7	2.5	3.1	2.9	2.7	2.6	2.4	2.9	2.7	2.6	2.5	2.4
300 x 57	4.0	3.8	3.5	3.3	3.2	3.8	3.6	3.4	3.2	3.0	3.6	3.4	3.2	3.1	2.9
300 x 75	4.2	3.9	3.7	3.5	3.3	4.0	3.7	3.6	3.4	3.2	3.8	3.6	3.4	3.2	3.1
350 x 57	4.6	4.3	4.1	3.9	3.7	4.3	4.1	3.9	3.8	3.6	4.1	3.9	3.8	3.7	3.5
400 x 57	5.0	4.6	4.4	4.2	4.0	4.7	4.4	4.2	4.1	3.9	4.5	4.3	4.1	4.0	3.8
400 x 75	5.2	4.8	4.6	4.4	4.2	4.9	4.6	4.4	4.2	4.1	4.7	4.4	4.3	4.1	4.0
450 x 57	5.4	5.1	4.8	4.6	4.4	5.1	4.8	4.6	4.4	4.3	4.9	4.7	4.5	4.3	4.2
Maximum continuous span (m)															
95 x 57	1.8	1.6	1.5	1.4	1.3	1.7	1.5	1.4	1.4	1.3	1.5	1.4	1.4	1.3	1.2
130 x 57	2.5	2.2	2.1	1.9	1.8	2.3	2.1	2.0	1.9	1.8	2.1	2.0	1.9	1.8	1.6
150 x 57	2.8	2.6	2.4	2.2	2.1	2.6	2.4	2.3	2.1	2.0	2.4	2.3	2.2	2.1	1.9
170 x 57	3.2	2.9	2.7	2.5	2.4	2.9	2.7	2.6	2.4	2.3	2.8	2.6	2.4	2.3	2.1
200 x 57	3.7	3.4	3.2	3.0	2.8	3.5	3.2	3.0	2.9	2.7	3.2	3.0	2.9	2.7	2.5
240 x 57	4.3	4.0	3.7	3.6	3.4	4.0	3.8	3.6	3.4	3.3	3.8	3.6	3.4	3.3	3.1
300 x 57	5.0	4.7	4.4	4.2	4.1	4.7	4.5	4.3	4.1	4.0	4.5	4.3	4.1	4.0	3.9
300 x 75	5.2	4.9	4.6	4.4	4.2	4.9	4.7	4.4	4.3	4.1	4.7	4.5	4.3	4.2	4.0
350 x 57	5.7	5.4	5.1	4.8	4.7	5.4	5.1	4.9	4.7	4.5	5.2	4.9	4.7	4.6	4.4
400 x 57	6.2	5.8	5.5	5.2	5.0	5.9	5.5	5.3	5.1	4.9	5.6	5.3	5.1	4.9	4.8
400 x 75	6.5	6.0	5.7	5.5	5.3	6.1	5.8	5.5	5.3	5.1	5.8	5.5	5.3	5.1	5.0
450 x 57	6.8	6.3	6.0	5.7	5.5	6.4	6.0	5.8	5.5	5.4	6.1	5.8	5.6	5.4	5.1

1. Sections with depth 200mm or greater must be restrained against rollover at supports.
2. Bearing length to be not less than 45mm at end supports or 90mm at intermediate supports for continuous span except where otherwise indicated by a subscript to the maximum span.
3. For single span bearers the subscript value indicates the required bearing length at end supports.
4. For continuous span, the subscript value indicates the minimum bearing length required at intermediate supports; the bearing length at end supports must be at least one third of the bearing length indicated for the intermediate support but not less than 45mm.

Bearers

Supporting Two Storey Load Bearing Walls For N3 wind classification

Tile Roof and Ceiling												
Ground Floor Load Width 'FLW' (m)												
e-beam Section D X B (mm)	1.5						3.0					
	First Floor Load Width 'FLW' (m)											
	1.5			3.0			1.5			3.0		
	Roof Load Width 'FLW' (m)											
	2.4	4.5	6.6	2.4	4.5	6.6	2.4	4.5	6.6	2.4	4.5	6.6
Maximum single span (m)												
95 x 57	1.1	1.0	0.9	1.0	0.9	0.9	1.0	0.9	0.9	1.0	0.9	0.8
2/90 x 42	1.2	1.1	1.0	1.1	1.0	0.9	1.1	1.0	0.9	1.0	1.0	0.9
130 x 57	1.5	1.4	1.3	1.4	1.3	1.2	1.4	1.3	1.2	1.3	1.2	1.2
2/130 x 42	1.7	1.5	1.4	1.6	1.4	1.4	1.6	1.4	1.4	1.5	1.4	1.3
150 x 57	1.7	1.6	1.5	1.6	1.5	1.4	1.6	1.5	1.4	1.5	1.4	1.3
2/150 x 42	1.9	1.8	1.6	1.8	1.7	1.6	1.8	1.7	1.6	1.7	1.6	1.5
170 x 57	2.0	1.8	1.7	1.8	1.7	1.6	1.8	1.7	1.6	1.7	1.6	1.5
2/170 x 42	2.2	2.0	1.9	2.0	1.9	1.8	2.0	1.9	1.8	1.9	1.8	1.7
200 x 57	2.3	2.1	1.9	2.1	2.0	1.9	2.1	2.0	1.9	2.0	1.9	1.8
2/200 x 42	2.6	2.4	2.2	2.4	2.2	2.1	2.4	2.2	2.1	2.2	2.1	2.0
240 x 57	2.8	2.5	2.3	2.6	2.4	2.2	2.6	2.4	2.2	2.4	2.2	2.1
2/240 x 42	3.1	2.8	2.6	2.9	2.7	2.5	2.9	2.7	2.5	2.7	2.5	2.4
300 x 57	3.4	3.1	2.9	3.2	3.0	2.8	3.2	3.0	2.8	3.0	2.8	2.7
300 x 75	3.6	3.3	3.1	3.4	3.1	2.9	3.4	3.1	2.9	3.2	3.0	2.8
Maximum continuous span (m)												
95 x 57	1.5	1.3	1.1	1.4	1.2	1.1	1.4	1.2	1.1	1.2	1.1	1.0
2/90 x 42	1.6	1.4	1.3	1.4	1.3	1.3	1.4	1.3	1.3	1.4	1.3	1.2
130 x 57	2.0	1.8	1.6	1.9	1.6	1.5	1.9	1.6	1.5	1.6	1.5	1.4
2/130 x 42	2.3	2.1	1.9	2.1	1.9	1.8	2.1	1.9	1.8	2.0	1.8	1.7
150 x 57	2.3	2.1	1.9	2.1	1.9	1.8	2.1	1.9	1.8	1.9	1.8	1.6
2/150 x 42	2.6	2.4	2.2	2.4	2.2	2.1	2.4	2.2	2.1	2.3	2.1	2.0
170 x 57	2.6	2.4	2.1	2.4	2.1	2.0	2.4	2.1	2.0	2.2	2.0	1.8
2/170 x 42	2.9	2.7	2.5	2.7	2.5	2.4	2.7	2.5	2.4	2.6	2.4	2.3
200 x 57	3.1	2.8	2.5	2.9	2.5	2.4	2.9	2.5	2.4	2.6	2.4	2.1
2/200 x 42	3.5	3.2	2.9	3.2	3.0	2.8	3.2	3.0	2.8	3.0	2.8	2.7
240 x 57	3.7	3.4	3.0	3.4	3.1	2.8	3.4	3.1	2.8	3.1	2.9	2.6
2/240 x 42	4.0	3.7	3.5	3.8	3.6	3.4	3.8	3.6	3.4	3.6	3.4	3.1
300 x 57	4.3	4.0	3.8	4.1	3.9	3.5	4.1	3.9	3.5	3.9	3.6	3.2
300 x 75	4.5	4.2	4.0	4.3	4.0	3.9	4.3	4.0	3.9	4.1	3.9	3.6

1. Sections with depth more than three times overall breadth must be restrained against rollover at supports.
2. Bearing length to be not less than 45mm at end supports or 90mm at intermediate supports for continuous span except where otherwise indicated by a subscript to the maximum span.
3. For single span bearers the subscript value indicates the required bearing length at end supports.
4. For continuous span, the subscript value indicates the minimum bearing length required at intermediate supports; the bearing length at end supports must be at least one third of the bearing length indicated for the intermediate support but not less than 45mm.

Bearers

Supporting Two Storey Load Bearing Walls For N3 wind classification

Sheet Roof and Ceiling												
Ground Floor Load Width 'FLW' (m)												
e-beam Section D X B (mm)	1.5						3.0					
	First Floor Load Width 'FLW' (m)											
	1.5			3.0			1.5			3.0		
	Roof Load Width 'FLW' (m)											
Roof Load Width 'FLW' (m)												
2.4												
4.5												
6.6												
2.4												
4.5												
6.6												
2.4												
4.5												
6.6												
Maximum single span (m)												
95 x 57	1.2	1.1	1.1	1.1	1.0	1.0	1.1	1.0	1.0	1.0	1.0	0.9
2/90 x 42	1.3	1.2	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.0	1.0
130 x 57	1.6	1.5	1.5	1.5	1.4	1.4	1.5	1.4	1.4	1.4	1.3	1.3
2/130 x 42	1.8	1.7	1.6	1.7	1.6	1.5	1.7	1.6	1.5	1.5	1.5	1.4
150 x 57	1.9	1.8	1.7	1.7	1.6	1.6	1.7	1.6	1.6	1.6	1.5	1.5
2/150 x 42	2.1	2.0	1.9	1.9	1.8	1.8	1.9	1.8	1.8	1.8	1.7	1.7
170 x 57	2.1	2.0	1.9	1.9	1.8	1.8	1.9	1.8	1.8	1.8	1.7	1.7
2/170 x 42	2.4	2.2	2.1	2.2	2.1	2.0	2.2	2.1	2.0	2.0	1.9	1.9
200 x 57	2.5	2.3	2.2	2.3	2.2	2.1	2.3	2.2	2.1	2.1	2.0	2.0
2/200 x 42	2.8	2.6	2.5	2.5	2.4	2.3	2.5	2.4	2.3	2.4	2.3	2.2
240 x 57	3.0	2.8	2.7	2.7	2.6	2.5	2.7	2.6	2.5	2.5	2.4	2.4
2/240 x 42	3.3	3.2	3.0	3.0	2.9	2.8	3.0	2.9	2.8	2.8	2.7	2.6
300 x 57	3.7	3.5	3.3	3.4	3.2	3.1	3.4	3.2	3.1	3.1	3.0	2.9
300 x 75	3.8	3.7	3.5	3.6	3.4	3.3	3.6	3.4	3.3	3.3	3.2	3.1
Maximum continuous span (m)												
95 x 57	1.6	1.5	1.4	1.4	1.4	1.3	1.4	1.4	1.3	1.2	1.2	1.2
2/90 x 42	1.7	1.6	1.5	1.5	1.5	1.4	1.5	1.5	1.4	1.4	1.4	1.3
130 x 57	2.2	2.0	2.0	2.0	1.9	1.8	2.0	1.9	1.8	1.7	1.7	1.6
2/130 x 42	2.4	2.3	2.2	2.2	2.1	2.0	2.2	2.1	2.0	2.1	2.0	1.9
150 x 57	2.5	2.4	2.3	2.3	2.2	2.1	2.3	2.2	2.1	2.0	1.9	1.9
2/150 x 42	2.8	2.7	2.5	2.6	2.4	2.4	2.6	2.4	2.4	2.4	2.3	2.2
170 x 57	2.8	2.7	2.6	2.6	2.5	2.4	2.6	2.5	2.4	2.3	2.2	2.1
2/170 x 42	3.2	3.0	2.9	2.9	2.8	2.7	2.9	2.8	2.7	2.7	2.6	2.5
200 x 57	3.3	3.1	3.0	3.0	2.9	2.8	3.0	2.9	2.8	2.7	2.6	2.5
2/200 x 42	3.7	3.5	3.4	3.4	3.3	3.1	3.4	3.3	3.1	3.2	3.1	3.0
240 x 57	3.9	3.7	3.6	3.6	3.5	3.3	3.6	3.5	3.3	3.3	3.2	3.1
2/240 x 42	4.2	4.1	3.9	4.0	3.8	3.7	4.0	3.8	3.7	3.7	3.6	3.5
300 x 57	4.6	4.4	4.2	4.3	4.1	4.0	4.3	4.1	4.0	4.0	3.9	3.9
300 x 75	4.8	4.6	4.4	4.5	4.3	4.2	4.5	4.3	4.2	4.2	4.1	4.0

1. Sections with depth more than three times overall breadth must be restrained against rollover at supports.
2. Bearing length to be not less than 45mm at end supports or 90mm at intermediate supports for continuous span except where otherwise indicated by a subscript to the maximum span.
3. For single span bearers the subscript value indicates the required bearing length at end supports.
4. For continuous span, the subscript value indicates the minimum bearing length required at intermediate supports; the bearing length at end supports must be at least one third of the bearing length indicated for the intermediate support but not less than 45mm.

Veneer

Species	Maritime Pine and/or Radiata Pine
Joints	Outer 2 plies are scarf jointed Inner plies – scarf and/or butt jointed

Moisture Content

8% - 15% (at time of despatch)

Density

650 kg/m³ (approximately)

Adhesive

Phenolic – AS 2754.1

Bond

Type A – AS/NZS 2098.2

Joint Group

JD3

Finish

Unsanded faces, sawn and arrised edges.

Branding

Each piece of e-beam is branded as least once with the product name for identification and evidence of compliance with manufacturing control standards

Storage

Store on level bearers at maximum 1800mm centres well clear of the ground, and cover to keep dry but allow ventilation

PO Box 217
Wanneroo, WA 6946
190 Pederick Road
Neerabup, WA 6031
Australia

